

SECTION 087100 – DOOR HARDWARE

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 1 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. This Section includes commercial door hardware for the following:
 - 1. Swinging doors.
 - 2. Other doors to the extent indicated.
- B. Door hardware includes, but is not necessarily limited to, the following:
 - 1. Mechanical door hardware.
 - 2. Electromechanical door hardware.
 - 3. Automatic operators.
 - 4. Cylinders specified for doors in other sections.
- C. Related Sections:
 - 1. Division 08 Section “Door Hardware Schedule”.
 - 2. Division 08 Section “Hollow Metal Doors and Frames”.
 - 3. Division 08 Section “Interior Aluminum Doors and Frames”.
 - 4. Division 08 Section “Flush Wood Doors”.
 - 5. Division 08 Section “Stile and Rail Wood Doors”.
- D. Codes and References: Comply with the version year adopted by the Authority Having Jurisdiction.
 - 1. ANSI A117.1 - Accessible and Usable Buildings and Facilities.
 - 2. ICC/IBC - International Building Code.
 - 3. NFPA 70 - National Electrical Code.
 - 4. NFPA 80 - Fire Doors and Windows.
 - 5. NFPA 101 - Life Safety Code.
 - 6. NFPA 105 - Installation of Smoke Door Assemblies.
 - 7. UL/ULC and CSA C22.2 – Standards for Automatic Door Operators Used on Fire and Smoke Barrier Doors and Systems of Doors.
 - 8. State Building Codes, Local Amendments.
- E. Standards: All hardware specified herein shall comply with the following industry standards:

1. ANSI/BHMA Certified Product Standards - A156 Series
2. UL10C – Positive Pressure Fire Tests of Door Assemblies

1.3 SUBMITTALS

- A. Product Data: Manufacturer's product data sheets including installation details, material descriptions, dimensions of individual components and profiles, operational descriptions and finishes.
- B. Door Hardware Schedule: Prepared by or under the supervision of supplier, detailing fabrication and assembly of door hardware, as well as procedures and diagrams. Coordinate the final Door Hardware Schedule with doors, frames, and related work to ensure proper size, thickness, hand, function, and finish of door hardware.
 1. Format: Comply with scheduling sequence and vertical format in DHI's "Sequence and Format for the Hardware Schedule."
 2. Organization: Organize the Door Hardware Schedule into door hardware sets indicating complete designations of every item required for each door or opening. Organize door hardware sets in same order as in the Door Hardware Sets at the end of Part 3. Submittals that do not follow the same format and order as the Door Hardware Sets will be rejected and subject to resubmission.
 3. Content: Include the following information:
 - a. Type, style, function, size, label, hand, and finish of each door hardware item.
 - b. Manufacturer of each item.
 - c. Fastenings and other pertinent information.
 - d. Location of door hardware set, cross-referenced to Drawings, both on floor plans and in door and frame schedule.
 - e. Explanation of abbreviations, symbols, and codes contained in schedule.
 - f. Mounting locations for door hardware.
 - g. Door and frame sizes and materials.
 - h. Warranty information for each product.
 4. Submittal Sequence: Submit the final Door Hardware Schedule at earliest possible date, particularly where approval of the Door Hardware Schedule must precede fabrication of other work that is critical in the Project construction schedule. Include Product Data, Samples, Shop Drawings of other work affected by door hardware, and other information essential to the coordinated review of the Door Hardware Schedule.
- C. Shop Drawings: Details of electrified access control hardware indicating the following:
 1. Wiring Diagrams: Upon receipt of approved schedules, submit detailed system wiring diagrams for power, signaling, monitoring, communication, and control of the access control system electrified hardware. Differentiate between manufacturer-installed and field-installed wiring. Include the following:

- a. Elevation diagram of each unique access controlled opening showing location and interconnection of major system components with respect to their placement in the respective door openings.
 - b. Complete (risers, point-to-point) access control system block wiring diagrams.
 - c. Wiring instructions for each electronic component scheduled herein.
 2. Electrical Coordination: Coordinate with related sections the voltages and wiring details required at electrically controlled and operated hardware openings.
 - D. Keying Schedule: After a keying meeting with the owner has taken place prepare a separate keying schedule detailing final instructions. Submit the keying schedule in electronic format. Include keying system explanation, door numbers, key set symbols, hardware set numbers and special instructions. Owner must approve submitted keying schedule prior to the ordering of permanent cylinders/cores.
 - E. Informational Submittals:
 1. Product Test Reports: Indicating compliance with cycle testing requirements, based on evaluation of comprehensive tests performed by manufacturer and witnessed by a qualified independent testing agency.
 - F. Operating and Maintenance Manuals: Provide manufacturers operating and maintenance manuals for each item comprising the complete door hardware installation in quantity as required in Division 01, Closeout Submittals.
- 1.4 QUALITY ASSURANCE
- A. Manufacturers Qualifications: Engage qualified manufacturers with a minimum 5 years of documented experience in producing hardware and equipment similar to that indicated for this Project and that have a proven record of successful in-service performance.
 - B. Installer Qualifications: A minimum 3 years documented experience installing both standard and electrified door hardware similar in material, design, and extent to that indicated for this Project and whose work has resulted in construction with a record of successful in-service performance.
 - C. Door Hardware Supplier Qualifications: Experienced commercial door hardware distributors with a minimum 5 years documented experience supplying both mechanical and electromechanical hardware installations comparable in material, design, and extent to that indicated for this Project. Supplier recognized as a factory direct distributor by the manufacturers of the primary materials with a warehousing facility in Project's vicinity. Supplier to have on staff a certified Architectural Hardware Consultant (AHC) available during the course of the Work to consult with Contractor, Architect, and Owner concerning both standard and electromechanical door hardware and keying.
 - D. Source Limitations: Obtain each type and variety of door hardware specified in this section from a single source unless otherwise indicated.

1. Electrified modifications or enhancements made to a source manufacturer's product line by a secondary or third party source will not be accepted.
 2. Provide electromechanical door hardware from the same manufacturer as mechanical door hardware, unless otherwise indicated.
- E. Each unit to bear third party permanent label demonstrating compliance with the referenced standards.
- F. Keying Conference: Conduct conference to comply with requirements in Division 01 Section "Project Meetings." Keying conference to incorporate the following criteria into the final keying schedule document:
1. Function of building, purpose of each area and degree of security required.
 2. Plans for existing and future key system expansion.
 3. Requirements for key control storage and software.
 4. Installation of permanent keys, cylinder cores and software.
 5. Address and requirements for delivery of keys.
- G. Pre-Submittal Conference: Conduct coordination conference in compliance with requirements in Division 01 Section "Project Meetings" with attendance by representatives of Supplier(s), Installer(s), and Contractor(s) to review proper methods and the procedures for receiving, handling, and installing door hardware.
1. Prior to installation of door hardware, conduct a project specific training meeting to instruct the installing contractors' personnel on the proper installation and adjustment of their respective products. Product training to be attended by installers of door hardware (including electromechanical hardware) for aluminum, hollow metal and wood doors. Training will include the use of installation manuals, hardware schedules, templates and physical product samples as required.
 2. Inspect and discuss electrical roughing-in, power supply connections, and other preparatory work performed by other trades.
 3. Review sequence of operation narratives for each unique access controlled opening.
 4. Review and finalize construction schedule and verify availability of materials.
 5. Review the required inspecting, testing, commissioning, and demonstration procedures
- H. At completion of installation, provide written documentation that components were applied to manufacturer's instructions and recommendations and according to approved schedule.

1.5 DELIVERY, STORAGE, AND HANDLING

- A. Inventory door hardware on receipt and provide secure lock-up and shelving for door hardware delivered to Project site. Do not store electronic access control hardware, software or accessories at Project site without prior authorization.
- B. Tag each item or package separately with identification related to the final Door Hardware Schedule, and include basic installation instructions with each item or package.

- C. Deliver, as applicable, permanent keys, cylinders, cores, access control credentials, software and related accessories directly to Owner via registered mail or overnight package service. Instructions for delivery to the Owner shall be established at the "Keying Conference".

1.6 COORDINATION

- A. Templates: Obtain and distribute to the parties involved templates for doors, frames, and other work specified to be factory prepared for installing standard and electrified hardware. Check Shop Drawings of other work to confirm that adequate provisions are made for locating and installing hardware to comply with indicated requirements.
- B. Door Hardware and Electrical Connections: Coordinate the layout and installation of scheduled electrified door hardware and related access control equipment with required connections to source power junction boxes, low voltage power supplies, detection and monitoring hardware, and fire and detection alarm systems.
- C. Door and Frame Preparation: Doors and corresponding frames are to be prepared, reinforced and pre-wired (if applicable) to receive the installation of the specified electrified, monitoring, signaling and access control system hardware without additional in-field modifications.

1.7 WARRANTY

- A. General Warranty: Reference Division 01, General Requirements. Special warranties specified in this Article shall not deprive Owner of other rights Owner may have under other provisions of the Contract Documents and shall be in addition to, and run concurrent with, other warranties made by Contractor under requirements of the Contract Documents.
- B. Warranty Period: Written warranty, executed by manufacturer(s), agreeing to repair or replace components of standard and electrified door hardware that fails in materials or workmanship within specified warranty period after final acceptance by the Owner. Failures include, but are not limited to, the following:
 - 1. Structural failures including excessive deflection, cracking, or breakage.
 - 2. Faulty operation of the hardware.
 - 3. Deterioration of metals, metal finishes, and other materials beyond normal weathering.
 - 4. Electrical component defects and failures within the systems operation.
- C. Standard Warranty Period: One year from date of Substantial Completion, unless otherwise indicated.
- D. Special Warranty Periods:
 - 1. Ten years for mortise locks and latches.
 - 2. Five years for exit hardware.
 - 3. Twenty five years for manual surface door closer bodies.
 - 4. Two years for electromechanical door hardware.

1.8 MAINTENANCE SERVICE

- A. Maintenance Tools and Instructions: Furnish a complete set of specialized tools and maintenance instructions as needed for Owner's continued adjustment, maintenance, and removal and replacement of door hardware.

PART 2 - PRODUCTS

2.1 SCHEDULED DOOR HARDWARE

- A. General: Provide door hardware for each door to comply with requirements in Door Hardware Sets and each referenced section that products are to be supplied under.
- B. Designations: Requirements for quantity, item, size, finish or color, grade, function, and other distinctive qualities of each type of door hardware are indicated in the Door Hardware Sets at the end of Part 3. Products are identified by using door hardware designations, as follows:
 - 1. Named Manufacturer's Products: Product designation and manufacturer are listed for each door hardware type required for the purpose of establishing requirements. Manufacturers' names are abbreviated in the Door Hardware Schedule.
- C. Substitutions: Requests for substitution and product approval for inclusive mechanical and electromechanical door hardware in compliance with the specifications must be submitted in writing and in accordance with the procedures and time frames outlined in Division 01, Substitution Procedures. Approval of requests is at the discretion of the architect, owner, and their designated consultants.

2.2 HANGING DEVICES

- A. Hinges: ANSI/BHMA A156.1 certified butt hinges with number of hinge knuckles as specified in the Door Hardware Sets.
 - 1. Quantity: Provide the following hinge quantity, unless otherwise indicated:
 - a. Two Hinges: For doors with heights up to 60 inches.
 - b. Three Hinges: For doors with heights 61 to 90 inches.
 - c. Four Hinges: For doors with heights 91 to 120 inches.
 - d. For doors with heights more than 120 inches, provide 4 hinges, plus 1 hinge for every 30 inches of door height greater than 120 inches.
 - 2. Hinge Size: Provide the following, unless otherwise indicated, with hinge widths sized for door thickness and clearances required:
 - a. Widths up to 3'0": 4-1/2" standard or heavy weight as specified.
 - b. Sizes from 3'1" to 4'0": 5" standard or heavy weight as specified.
 - 3. Hinge Weight and Base Material: Unless otherwise indicated, provide the following:

- a. Exterior Doors: Heavy weight, non-ferrous, ball bearing or oil impregnated bearing hinges unless Hardware Sets indicate standard weight.
 - b. Interior Doors: Standard weight, steel, ball bearing or oil impregnated bearing hinges unless Hardware Sets indicate heavy weight.
 - 4. Hinge Options: Comply with the following:
 - a. Non-removable Pins: Provide set screw in hinge barrel that, when tightened into a groove in hinge pin, prevents removal of pin while door is closed; for the all out-swinging lockable doors.
 - 5. Acceptable Manufacturers:
 - a. Bommer Industries (BO).
 - b. Hager Companies (HA).
 - c. McKinney Products; ASSA ABLOY Architectural Door Accessories (MK).
- B. Continuous Geared Hinges: ANSI/BHMA A156.26 Grade 1-600 certified continuous geared hinge. with minimum 0.120-inch thick extruded 6060 T6 aluminum alloy hinge leaves and a minimum overall width of 4 inches. Hinges are non-handed, reversible and fabricated to template screw locations. Factory trim hinges to suit door height and prepare for electrical cut-outs.
- 1. Acceptable Manufacturers:
 - a. Bommer Industries (BO).
 - b. McKinney Products; ASSA ABLOY Architectural Door Accessories (MK).
 - c. Pemko Products; ASSA ABLOY Architectural Door Accessories (PE).

2.3 DOOR OPERATING TRIM

- A. Flush Bolts and Surface Bolts: ANSI/BHMA A156.3 and A156.16, Grade 1, certified.
- 1. Flush bolts to be furnished with top rod of sufficient length to allow bolt retraction device location approximately six feet from the floor.
 - 2. Furnish dust proof strikes for bottom bolts.
 - 3. Surface bolts to be minimum 8" in length and U.L. listed for labeled fire doors and U.L. listed for windstorm components where applicable.
 - 4. Provide related accessories (mounting brackets, strikes, coordinators, etc.) as required for appropriate installation and operation.
 - 5. Acceptable Manufacturers:
 - a. Door Controls International (DC).
 - b. Rockwood Products; ASSA ABLOY Architectural Door Accessories (RO).
 - c. Trimco (TC).
- B. Coordinators: ANSI/BHMA A156.3 certified door coordinators consisting of active-leaf, hold-open lever and inactive-leaf release trigger. Model as indicated in hardware sets.

1. Acceptable Manufacturers:

- a. Door Controls International (DC).
- b. Rockwood Products; ASSA ABLOY Architectural Door Accessories (RO).
- c. Trimco (TC).

C. Door Push Plates and Pulls: ANSI/BHMA A156.6 certified door pushes and pulls of type and design specified in the Hardware Sets. Coordinate and provide proper width and height as required where conflicting hardware dictates.

1. Push/Pull Plates: Minimum .050 inch thick, size as indicated in hardware sets, with beveled edges, secured with exposed screws unless otherwise indicated.
2. Door Pull and Push Bar Design: Size, shape, and material as indicated in the hardware sets. Minimum clearance of 2 1/2-inches from face of door unless otherwise indicated.
3. Offset Pull Design: Size, shape, and material as indicated in the hardware sets. Minimum clearance of 2 1/2-inches from face of door and offset of 90 degrees unless otherwise indicated.
4. Fasteners: Provide manufacturer's designated fastener type as indicated in Hardware Sets.
5. Acceptable Manufacturers:
 - a. Hiawatha, Inc. (HI).
 - b. Rockwood Products; ASSA ABLOY Architectural Door Accessories (RO).
 - c. Trimco (TC).

2.4 CYLINDERS AND KEYING

- A. General: Cylinder manufacturer to have minimum (10) years experience designing secured master key systems and have on record a published security keying system policy.
- B. Source Limitations: Obtain each type of keyed cylinder and keys from the same source manufacturer as locksets and exit devices, unless otherwise indicated.
- C. Cylinders: Original manufacturer cylinders complying with the following:
 1. Mortise Type: Threaded cylinders with rings and cams to suit hardware application.
 2. Rim Type: Cylinders with back plate, flat-type vertical or horizontal tailpiece, and raised trim ring.
 3. Bored-Lock Type: Cylinders with tailpieces to suit locks.
 4. Mortise and rim cylinder collars to be solid and recessed to allow the cylinder face to be flush and be free spinning with matching finishes.
 5. Keyway: Manufacturer's Standard.
- D. Patented Cylinders: ANSI/BHMA A156.5, Grade 1, certified patented cylinders employing a utility patented and restricted keyway requiring the use of a patented key. Cylinders are to be protected from unauthorized manufacture and distribution by manufacturer's United States patents. Cylinders are to be factory keyed with owner having the ability for on-site original key cutting.

1. Acceptable Manufacturers:
 - a. Medeco (MC) - X4 Series.
- E. Patented Cylinders: ANSI/BHMA A156.5, Grade 1, certified cylinders employing a utility patented and restricted keyway requiring the use of patented controlled keys. Provide bump resistant, fixed core cylinders as standard with solid recessed cylinder collars. Cylinders are to be factory keyed where permanent keying records will be established and maintained.
 1. Provide a 6 pin multi-level master key system comprised of patented controlled keys and security and high security cylinders operated by one (1) key of the highest level. Geographical exclusivity to be provided for all security and high security cylinders and UL437 certification where specified.
 - a. Level 1 Cylinders: Provide utility patented controlled keyway cylinders that are furnished with patented keys available only from authorized distribution.
 - b. Level 2 Cylinders: Provide utility patented controlled keyway and side bar locking incorporating unique angled bottom pins for geographical exclusivity. Cylinders constructed to provide protection against bumping and picking.
 - c. Level 3 Cylinders: Provide utility patented controlled keyway and side bar locking incorporating unique angled bottom pins for geographical exclusivity. Cylinders to be UL437 certified and constructed to provide protection against bumping, picking, and drilling.
 - d. Refer to hardware sets for specified levels.
2. Acceptable Manufacturers:
 - a. Sargent Manufacturing (SA) - Degree Series.
 - b. Corbin Russwin (RU) – Access 3 Series.
- F. Keying System: Each type of lock and cylinders to be factory keyed.
 1. Conduct specified "Keying Conference" to define and document keying system instructions and requirements.
 2. Furnish factory cut, nickel-silver large bow permanently inscribed with a visual key control number as directed by Owner.
 3. New System: Key locks to a new key system as directed by the Owner.
- G. Key Quantity: Provide the following minimum number of keys:
 1. Change Keys per Cylinder: Two (2)
 2. Master Keys (per Master Key Level/Group): Five (5).
 3. Construction Keys (where required): Ten (10).
- H. Construction Keying: Provide construction master keyed cylinders.
- I. Key Registration List (Bitting List):
 1. Provide keying transcript list to Owner's representative in the proper format for importing into key control software.

2. Provide transcript list in writing or electronic file as directed by the Owner.

- J. Key Control Cabinet: Provide a key control system including envelopes, labels, and tags with self-locking key clips, receipt forms, 3-way visible card index, temporary markers, permanent markers, and standard metal cabinet. Key control cabinet shall have expansion capacity of 150% of the number of locks required for the project.

1. Acceptable Manufacturers:

- a. Lund Equipment (LU).
- b. MMF Industries (MM).
- c. Telkee (TK).

- K. Key Control Software: Provide one network version of "Key Wizard" branded key management software package that includes one year of technical support and upgrades to software at no charge. Provide factory key system formatted for importing into "Key Wizard" software.

2.5 MECHANICAL LOCKS AND LATCHING DEVICES

- A. Mortise Locksets, Grade 1 (Heavy Duty): ANSI/BHMA A156.13, Series 1000, Operational Grade 1 certified. Locksets are to be manufactured with a corrosion resistant steel case and be field-reversible for handing without disassembly of the lock body.

1. Acceptable Manufacturers:

- a. Corbin Russwin Hardware (RU) – ML2000 Series.
- b. Sargent Manufacturing (SA) – 8200 Series.
- c. Yale Locks and Hardware (YA) – 8800FL Series.

- B. Residential Tubular Locking Devices: Standard ANSI A156.2, Series 4000, Grade 2.

1. Tubular locksets, deadbolts, and handlesets designed to fit ANSI standard door preps.

2. Locks are to be non-handed and have adjustable backset.

3. Acceptable Manufacturers:

- a. Yale Residential (YR) - YH Series.

2.6 AUXILIARY LOCKS

- A. Mortise Deadlocks, Large Case: ANSI/BHMA A156.13, Series 1000, Grade 1, certified large case mortise type deadlocks constructed of heavy gauge wrought corrosion resistant steel. One piece stainless steel bolts with a 1" throw. Deadlocks to be products of the same source manufacturer and keyway as other locksets.

1. Acceptable Manufacturers:

- a. Corbin Russwin Hardware (RU) - ML2000 Series.
- b. Sargent Manufacturing (SA) - 8200 Series.
- c. Yale Locks and Hardware (YA) - 8800 Series.

2.7 LOCK AND LATCH STRIKES

- A. Strikes: Provide manufacturer's standard strike with strike box for each latch or lock bolt, with curved lip extended to protect frame, finished to match door hardware set, unless otherwise indicated, and as follows:
 - 1. Flat-Lip Strikes: For locks with three-piece antifriction latchbolts, as recommended by manufacturer.
 - 2. Extra-Long-Lip Strikes: For locks used on frames with applied wood casing trim.
 - 3. Aluminum-Frame Strike Box: Provide manufacturer's special strike box fabricated for aluminum framing.
 - 4. Double-lipped strikes: For locks at double acting doors. Furnish with retractable stop for rescue hardware applications.
- B. Standards: Comply with the following:
 - 1. Strikes for Mortise Locks and Latches: BHMA A156.13.
 - 2. Strikes for Bored Locks and Latches: BHMA A156.2.
 - 3. Strikes for Auxiliary Deadlocks: BHMA A156.36.
 - 4. Dustproof Strikes: BHMA A156.16.

2.8 CONVENTIONAL EXIT DEVICES

- A. General Requirements: All exit devices specified herein shall meet or exceed the following criteria:
 - 1. At doors not requiring a fire rating, provide devices complying with NFPA 101 and listed and labeled for "Panic Hardware" according to UL305. Provide proper fasteners as required by manufacturer including sex nuts and bolts at openings specified in the Hardware Sets.
 - 2. Where exit devices are required on fire rated doors, provide devices complying with NFPA 80 and with UL labeling indicating "Fire Exit Hardware". Provide devices with the proper fasteners for installation as tested and listed by UL. Consult manufacturer's catalog and template book for specific requirements.
 - 3. Except on fire rated doors, provide exit devices with hex key dogging device to hold the pushbar and latch in a retracted position. Provide optional keyed cylinder dogging on devices where specified in Hardware Sets.
 - 4. Devices must fit flat against the door face with no gap that permits unauthorized dogging of the push bar. The addition of filler strips is required in any case where the door light extends behind the device as in a full glass configuration.

5. Lever Operating Trim: Where exit devices require lever trim, furnish manufacturer's heavy duty escutcheon trim with threaded studs for thru-bolts.
 - a. Lock Trim Design: As indicated in Hardware Sets, provide finishes and designs to match that of the specified locksets.
 - b. Where function of exit device requires a cylinder, provide a cylinder (Rim or Mortise) as specified in Hardware Sets.
 6. Vertical Rod Exit Devices: Where surface or concealed vertical rod exit devices are used at interior openings, provide as less bottom rod (LBR) unless otherwise indicated. Provide dust proof strikes where thermal pins are required to project into the floor.
 7. Narrow Stile Applications: At doors constructed with narrow stiles, or as specified in Hardware Sets, provide devices designed for maximum 2" wide stiles.
 8. Dummy Push Bar: Nonfunctioning push bar matching functional push bar.
 9. Rail Sizing: Provide exit device rails factory sized for proper door width application.
 10. Through Bolt Installation: For exit devices and trim as indicated in Door Hardware Sets.
- B. Conventional Push Rail Exit Devices (Heavy Duty): ANSI/BHMA A156.3, Grade 1 certified panic and fire exit hardware devices furnished in the functions specified in the Hardware Sets. Exit device latch to be stainless steel, pullman type, with deadlock feature.
1. Acceptable Manufacturers:
 - a. Corbin Russwin Hardware (RU) - ED4000 / ED5000 Series.
 - b. Sargent Manufacturing (SA) - 80 Series.
- C. Conventional Push Rail Exit Devices (Commercial Duty): ANSI/BHMA A156.3, Grade 1 certified panic and fire exit hardware devices furnished in the functions specified in the Hardware Sets. Fabricate latchbolts from cast stainless steel, Pullman type, incorporating a deadlocking feature.
1. Acceptable Manufacturers:
 - a. Yale Locks and Hardware (YA) - 6000 Series.

2.9 DOOR CLOSERS

- A. All door closers specified herein shall meet or exceed the following criteria:
1. General: Door closers to be from one manufacturer, matching in design and style, with the same type door preparations and templates regardless of application or spring size. Closers to be non-handed with full sized covers including installation and adjusting information on inside of cover.

2. Standards: Closers to comply with UL-10C for Positive Pressure Fire Test and be U.L. listed for use of fire rated doors.
 3. Cycle Testing: Provide closers which have surpassed 15 million cycles in a test witnessed and verified by UL.
 4. Size of Units: Comply with manufacturer's written recommendations for sizing of door closers depending on size of door, exposure to weather, and anticipated frequency of use. Where closers are indicated for doors required to be accessible to the physically handicapped, provide units complying with ANSI ICC/A117.1.
 5. Closer Arms: Provide heavy duty, forged steel closer arms unless otherwise indicated in Hardware Sets.
 6. Closers shall not be installed on exterior or corridor side of doors; where possible install closers on door for optimum aesthetics.
 7. Closer Accessories: Provide door closer accessories including custom templates, special mounting brackets, spacers and drop plates as required for proper installation. Provide through-bolt and security type fasteners as specified in the hardware sets.
- B. Door Closers, Surface Mounted (Heavy Duty): ANSI/BHMA A156.4, Grade 1 surface mounted, heavy duty door closers with complete spring power adjustment, sizes 1 thru 6; and fully operational adjustable according to door size, frequency of use, and opening force. Closers to be rack and pinion type, one piece cast iron or aluminum alloy body construction, with adjustable backcheck and separate non-critical valves for closing sweep and latch speed control. Provide non-handed units standard.
1. Acceptable Manufacturers:
 - a. Corbin Russwin Hardware (RU) – DC6000 Series.
 - b. Sargent Manufacturing (SA) - 351 Series.
 - c. Norton Door Controls (NO) - 7500 Series.
- C. Door Closers, Surface Mounted (Commercial Duty): ANSI/BHMA 156.4, Grade 1 certified surface mounted, institutional grade door closers with complete spring power adjustment, sizes 1 thru 6; and fully operational adjustable according to door size, frequency of use, and opening force. Closers to be rack and pinion type, one piece cast iron or aluminum alloy body construction, with adjustable backcheck, closing sweep, and latch speed control valves. Provide non-handed units standard.
1. Acceptable Manufacturers:
 - a. Corbin Russwin Hardware (RU) - DC6000 Series.
 - b. Norton Door Controls (NO) - 8500 Series.
 - c. Sargent Manufacturing (SA) - 1431 Series.
- D. Door Closers, Surface Mounted (Light Commercial): ANSI/BHMA 156.4, Grade 1 and 2 surface mounted, light commercial grade door closers. Non-handed, minimum sizes 2 to 4

Provide closer standard packed for regular, top-jamb, and parallel arm type mounting applications.

1. Acceptable Manufacturers:
 - a. Norton Door Controls (NO) - 1700 Series.
 - b. Yale Locks and Hardware (YA) - 1100 Series.

2.10 ELECTROHYDRAULIC DOOR OPERATORS

- A. General: Provide low energy operators of size recommended by manufacturer for door size, weight, and movement; for condition of exposure; and for compliance with UL 325. Coordinate operator mechanisms with door operation, hinges, and activation devices.
 1. Fire-Rated Doors: Provide door operators for fire-rated door assemblies that comply with NFPA 80 for fire-rated door components and are listed and labeled by a qualified testing agency.
- B. Standard: Certified ANSI/BHMA A156.19.
- C. Performance Requirements:
 1. Opening Force if Power Fails: Not more than 15 lbf required to release a latch if provided, not more than 30 lbf required to manually set door in motion, and not more than 15 lbf required to fully open door.
 2. Entrapment Protection: Not more than 15 lbf required to prevent stopped door from closing or opening.
- D. Configuration: Surface mounted or in-ground as required. Door operators to control single swinging and pair of swinging doors.
- E. Operation: Power opening and spring closing operation capable of meeting ANSI A117.1 accessibility guideline. Provide time delay for door to remain open before initiating closing cycle as required by ANSI/BHMA A156.19. When not in automatic mode, door operator to function as manual door closer with fully adjustable opening and closing forces, with or without electrical power.
- F. Features: Operator units to have full feature adjustments for door opening and closing force and speed, backcheck, motor assist acceleration from 0 to 30 seconds, time delay, vestibule interface delay, obstruction recycle, and hold open time from 0 up to 30 seconds.
- G. Provide outputs and relays on board the operator to allow for coordination of exit device latch retraction, electric strikes, magnetic locks, card readers, safety and motion sensors and specified auxiliary contacts.
- H. Brackets and Reinforcements: Manufacturer's standard, fabricated from aluminum with nonferrous shims for aligning system components.

- I. Acceptable Manufacturers: Subject to compliance with requirements, provide products by one of the following:

1. Norton Door Controls (NO) - 6000 Series.

2.11 ARCHITECTURAL TRIM

A. Door Protective Trim

1. General: Door protective trim units to be of type and design as specified below or in the Hardware Sets.
2. Size: Fabricate protection plates (kick, armor, or mop) not more than 2" less than door width (LDW) on stop side of single doors and 1" LDW on stop side of pairs of doors, and not more than 1" less than door width on pull side. Coordinate and provide proper width and height as required where conflicting hardware dictates. Height to be as specified in the Hardware Sets.
3. Where plates are applied to fire rated doors with the top of the plate more than 16" above the bottom of the door, provide plates complying with NFPA 80. Consult manufacturer's catalog and template book for specific requirements for size and applications.
4. Protection Plates: ANSI/BHMA A156.6 certified protection plates (kick, armor, or mop), fabricated from the following:
 - a. Stainless Steel: 300 grade, .050-inch thick.
5. Options and fasteners: Provide manufacturer's designated fastener type as specified in the Hardware Sets. Provide countersunk screw holes.
6. Acceptable Manufacturers:
 - a. Hiawatha, Inc. (HI).
 - b. Rockwood Products; ASSA ABLOY Architectural Door Accessories (RO).
 - c. Trimco (TC).

2.12 DOOR STOPS AND HOLDERS

- A. General: Door stops and holders to be of type and design as specified below or in the Hardware Sets.
- B. Door Stops and Bumpers: ANSI/BHMA A156.16, Grade 1 certified door stops and wall bumpers. Provide wall bumpers, either convex or concave types with anchorage as indicated, unless floor or other types of door stops are specified in Hardware Sets. Do not mount floor stops where they will impede traffic. Where floor or wall bumpers are not appropriate, provide overhead type stops and holders.
 1. Acceptable Manufacturers:

- a. Hiawatha, Inc. (HI).
 - b. Rockwood Products; ASSA ABLOY Architectural Door Accessories (RO).
 - c. Trimco (TC).
- C. Overhead Door Stops and Holders: ANSI/BHMA A156.6, Grade 1 certified overhead stops and holders to be surface or concealed types as indicated in Hardware Sets. Track, slide, arm and jamb bracket to be constructed of extruded bronze and shock absorber spring of heavy tempered steel. Provide non-handed design with mounting brackets as required for proper operation and function.
 - 1. Acceptable Manufacturers:
 - a. Rixson Door Controls (RF).
 - b. Rockwood Products; ASSA ABLOY Architectural Door Accessories (RO).
 - c. Sargent Manufacturing (SA).

2.13 ARCHITECTURAL SEALS

- A. General: Thresholds, weatherstripping, and gasket seals to be of type and design as specified below or in the Hardware Sets. Provide continuous weatherstrip gasketing on exterior doors and provide smoke, light, or sound gasketing on interior doors where indicated. At exterior applications provide non-corrosive fasteners and elsewhere where indicated.
- B. Smoke Labeled Gasketing: Assemblies complying with NFPA 105 that are listed and labeled by a testing and inspecting agency acceptable to authorities having jurisdiction, for smoke control ratings indicated, based on testing according to UL 1784.
 - 1. Provide smoke labeled perimeter gasketing at all smoke labeled openings.
- C. Fire Labeled Gasketing: Assemblies complying with NFPA 80 that are listed and labeled by a testing and inspecting agency acceptable to authorities having jurisdiction, for fire ratings indicated, based on testing according to UL-10C.
 - 1. Provide intumescent seals as indicated to meet UL10C Standard for Positive Pressure Fire Tests of Door Assemblies, and NFPA 252, Standard Methods of Fire Tests of Door Assemblies.
- D. Sound-Rated Gasketing: Assemblies that are listed and labeled by a testing and inspecting agency, for sound ratings indicated.
- E. Replaceable Seal Strips: Provide only those units where resilient or flexible seal strips are easily replaceable and readily available from stocks maintained by manufacturer.
- F. Acceptable Manufacturers:
 - 1. National Guard Products (NG).
 - 2. Pemko Products; ASSA ABLOY Architectural Door Accessories (PE).
 - 3. Reese Enterprises, Inc. (RE).

2.14 FABRICATION

- A. Fasteners: Provide door hardware manufactured to comply with published templates generally prepared for machine, wood, and sheet metal screws. Provide screws according to manufacturers recognized installation standards for application intended.

2.15 FINISHES

- A. Standard: Designations used in the Hardware Sets and elsewhere indicate hardware finishes complying with ANSI/BHMA A156.18, including coordination with traditional U.S. finishes indicated by certain manufacturers for their products.
- B. Provide quality of finish, including thickness of plating or coating (if any), composition, hardness, and other qualities complying with manufacturer's standards, but in no case less than specified by referenced standards for the applicable units of hardware
- C. Protect mechanical finishes on exposed surfaces from damage by applying a strippable, temporary protective covering before shipping.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine scheduled openings, with Installer present, for compliance with requirements for installation tolerances, labeled fire door assembly construction, wall and floor construction, and other conditions affecting performance.
- B. Notify architect of any discrepancies or conflicts between the door schedule, door types, drawings and scheduled hardware. Proceed only after such discrepancies or conflicts have been resolved in writing.

3.2 PREPARATION

- A. Hollow Metal Doors and Frames: Comply with ANSI/DHI A115 series.
- B. Wood Doors: Comply with ANSI/DHI A115-W series.

3.3 INSTALLATION

- A. Install each item of mechanical and electromechanical hardware and access control equipment to comply with manufacturer's written instructions and according to specifications.
 - 1. Installers are to be trained and certified by the manufacturer on the proper installation and adjustment of fire, life safety, and security products including: hanging devices; locking devices; closing devices; and seals.

- B. Mounting Heights: Mount door hardware units at heights indicated in following applicable publications, unless specifically indicated or required to comply with governing regulations:
 - 1. Standard Steel Doors and Frames: DHI's "Recommended Locations for Architectural Hardware for Standard Steel Doors and Frames."
 - 2. Wood Doors: DHI WDHS.3, "Recommended Locations for Architectural Hardware for Wood Flush Doors."
 - 3. Where indicated to comply with accessibility requirements, comply with ANSI A117.1 "Accessibility Guidelines for Buildings and Facilities."
 - 4. Provide blocking in drywall partitions where wall stops or other wall mounted hardware is located.
- C. Retrofitting: Install door hardware to comply with manufacturer's published templates and written instructions. Where cutting and fitting are required to install door hardware onto or into surfaces that are later to be painted or finished in another way, coordinate removal, storage, and reinstallation of surface protective trim units with finishing work specified in Division 9 Sections. Do not install surface-mounted items until finishes have been completed on substrates involved.
- D. Thresholds: Set thresholds for exterior and acoustical doors in full bed of sealant complying with requirements specified in Division 7 Section "Joint Sealants."
- E. Storage: Provide a secure lock up for hardware delivered to the project but not yet installed. Control the handling and installation of hardware items so that the completion of the work will not be delayed by hardware losses before and after installation.

3.4 FIELD QUALITY CONTROL

- A. Field Inspection: Supplier will perform a final inspection of installed door hardware and state in report whether work complies with or deviates from requirements, including whether door hardware is properly installed, operating and adjusted.

3.5 ADJUSTING

- A. Initial Adjustment: Adjust and check each operating item of door hardware and each door to ensure proper operation or function of every unit. Replace units that cannot be adjusted to operate as intended. Adjust door control devices to compensate for final operation of heating and ventilating equipment and to comply with referenced accessibility requirements.

3.6 CLEANING AND PROTECTION

- A. Protect all hardware stored on construction site in a covered and dry place. Protect exposed hardware installed on doors during the construction phase. Install any and all hardware at the latest possible time frame.
- B. Clean adjacent surfaces soiled by door hardware installation.

- C. Clean operating items as necessary to restore proper finish. Provide final protection and maintain conditions that ensure door hardware is without damage or deterioration at time of owner occupancy.

3.7 DEMONSTRATION

- A. Instruct Owner's maintenance personnel to adjust, operate, and maintain mechanical and electromechanical door hardware.

3.8 DOOR HARDWARE SETS

- A. The hardware sets represent the design intent and direction of the owner and architect. They are a guideline only and should not be considered a detailed hardware schedule. Discrepancies, conflicting hardware and missing items should be brought to the attention of the architect with corrections made prior to the bidding process. Omitted items not included in a hardware set should be scheduled with the appropriate additional hardware required for proper application and functionality.

Hardware Sets

Set: 1.0

Doors: 102-1A/B

2 Continuous Hinge	CFM95HD1		PE
1 Concealed Vert Rod Exit	DG1 16 AD8410	US32D	SA
1 Concealed Vert Rod Exit	AD8410 106	US32D	SA
3 Cylinder	DG1 42/ 34	US32D	SA
2 Surface Closer	CPS8501 (Drop plate and adapters as required)	689	NO
1 Weatherstrip	By Dr/ Frame Mfg.		00

Set: 2.0

Doors: 118-1A/B

2 Surface Closer	CPS7500 (Black Finish) (Drop plate and adapters as required)	600 x 693	NO
------------------	--	-----------	----

Notes: REMAINDER OF HARDWARE BY DOOR MANUFACTURER.

Set: 3.0

Doors: 009-1, 009-2

1 Door Operator	6020 D (Black)	600 x 693	NO
1 Wall Switch	700 (Wave to open)		NO

Notes: ACTUATING WAVE TO OPEN WALL SWITCH WILL ACTIVATE OPERATOR. WALL SWITCH ON EACH SIDE OF OPERATORS.
REMAINDER OF HARDWARE BY DOOR MANUFACTURER.

Set: 4.0

Doors: 101-1, 118-2

1 Surface Closer	CPS7500 (Black Finish) (Drop plate and adapters as required)	600 x 693	NO
------------------	--	-----------	----

Notes: REMAINDER OF HARDWARE BY DOOR MANUFACTURER.

Set: 5.0

Doors: 101-2

1 Continuous Hinge	CFM95HD1		PE
1 Push Bar	RM350 Mtg-Type 12XHD	US32D-316	RO
1 Pull	RM201 Mtg-Type 12XHD	US32D-316	RO
1 Surface Closer	CLP8501 (Drop plate and adapters as required)	689	NO
1 Weatherstrip	By Dr/ Frame Mfg.		00

Set: 6.0

Doors: 105-2

1 Continuous Hinge	CFM95HD1		PE
1 Storeroom Lock	DG1 8204 LNNJ	US26D	SA
1 Kick Plate	K1050 10" HIGH 4BE CSK	US32D	RO
1 Threshold	1715A		PE
1 Gasketing	S88D (Head & Jambs)		PE
1 Sweep	307APK		PE

Set: 7.0

Doors: 107-1, 108-1, 109-2, 109-3

1 Continuous Hinge	CFM95HD1		PE
1 Mortise Deadlock	MS1850S	628	AD
1 Cylinder	4066-01	130	AD
1 Cylinder	DG1 42/ 34	US32D	SA
1 Push Bar	RM350 Mtg-Type 12XHD	US32D-316	RO
1 Pull	RM201 Mtg-Type 12XHD	US32D-316	RO
1 Surface Closer	CPS8501 (Drop plate and adapters as required)	689	NO
1 Threshold	171A MS10SS		PE
1 Weatherstrip	By Dr/ Frame Mfg.		00
1 Sweep	307APK		PE

Set: 8.0

Doors: 404-1

3 Hinge	TA2714 NRP	US26D	MK
1 Rim Exit Device	DG1 16 8804 ETNJ	US32D	SA
2 Cylinder	DG1 42/ 34	US32D	SA
1 Surface Closer	CPS8501 (Drop plate and adapters as required)	689	NO
1 Kick Plate	K1050 10" HIGH 4BE CSK	US32D	RO
1 Gasketing	S88D (Head & Jambs)		PE

Set: 9.0

Doors: ST-1-0, ST-1-1, ST-2-0

3 Hinge (heavy weight)	T4A3786 NRP	US26D	MK
1 Rim Exit Device	DG1 12 8804 ETNJ	US32D	SA
1 Cylinder	DG1 42/ 34	US32D	SA
1 Surface Closer	CPS8501 (Drop plate and adapters as required)	689	NO
1 Kick Plate	K1050 10" HIGH 4BE CSK	US32D	RO
1 Gasketing	S88D (Head & Jambs)		PE

Set: 10.0

Doors: 109-1

3 Hinge (heavy weight)	T4A3786 NRP	US26D	MK
1 Rim Exit Device	LD 8815 ETNJ	US32D	SA
1 Surface Closer	8501/ (PA) 8501 (Drop plate and adapters as required)	689	NO
1 Kick Plate	K1050 10" HIGH 4BE CSK	US32D	RO
1 Door Stop	409	US32D	RO
1 Gasketing	S88D (Head & Jambs)		PE

Set: 11.0

Doors: 407-1, ST-1-2, ST-1-3, ST-1-4, ST-2-1, ST-2-2, ST-2-3, ST-2-4

3 Hinge (heavy weight)	T4A3786	US26D	MK
1 Rim Exit Device	12 8815 ETNJ	US32D	SA
1 Surface Closer	8501/ (PA) 8501 (Drop plate and adapters as required)	689	NO
1 Door Stop	409	US32D	RO
1 Gasketing	S88D (Head & Jambs)		PE

Set: 12.0

Doors: 003-1

6 Hinge	TA2714	US26D	MK
2 Flush Bolt	555/557	US26D	RO
1 Dust Proof Strike	570	US26D	RO
1 Storeroom Lock	DG1 8204 LNNJ	US26D	SA
2 Surface Closer	8501H (Drop plate and adapters as required)	689	NO
2 Kick Plate	K1050 10" HIGH 4BE CSK	US32D	RO
2 Door Stop	409	US32D	RO
1 Gasketing	S88D (Head & Jambs)		PE
1 Astragal	S771C x Door Height		PE

Set: 13.0

Doors: 010-1

6 Hinge	TA2714	US26D	MK
2 Flush Bolt	555/557	US26D	RO
1 Dust Proof Strike	570	US26D	RO
1 Storeroom Lock	DG1 8204 LNNJ	US26D	SA
2 Surface Closer	CLP8501T (Drop plate and adapters as required)	689	NO

2 Kick Plate	K1050 10" HIGH 4BE CSK	US32D	RO
2 Door Stop	409	US32D	RO
1 Gasketing	S88D (Head & Jambs)		PE
1 Astragal	S771C x Door Height		PE

Set: 14.0

Doors: 006-1

3 Hinge	TA2714 NRP	US26D	MK
1 Storeroom Lock	DG1 8204 LNNJ	US26D	SA
1 Door Stop	409	US32D	RO
3 Silencer	608		RO

Set: 15.0

Doors: 114-1

3 Hinge	TA2714	US26D	MK
1 Storeroom Lock	DG1 8204 LNNJ	US26D	SA
1 Surface Closer	8501/ (PA) 8501 (Drop plate and adapters as required)	689	NO
1 Kick Plate	K1050 10" HIGH 4BE CSK	US32D	RO
1 Door Stop	409	US32D	RO
3 Silencer	608		RO

Set: 16.0

Doors: 002-1

3 Hinge	TA2714	US26D	MK
1 Storeroom Lock	DG1 8204 LNNJ	US26D	SA
1 Surface Closer	8501H (Drop plate and adapters as required)	689	NO
1 Kick Plate	K1050 10" HIGH 4BE CSK	US32D	RO
1 Door Stop	409	US32D	RO
3 Silencer	608		RO

Set: 17.0

Doors: 004-1

3 Hinge	TA2714	US26D	MK
1 Storeroom Lock	DG1 8204 LNNJ	US26D	SA

1 Surface Closer	CLP8501T (Drop plate and adapters as required)	689	NO
1 Kick Plate	K1050 10" HIGH 4BE CSK	US32D	RO
1 Door Stop	409	US32D	RO
3 Silencer	608		RO

Set: 18.0

Doors: 105-1, 106A-1

3 Hinge	TA2714	US26D	MK
1 Storeroom Lock	DG1 8204 LNNJ	US26D	SA
1 Surface Closer	8501/ (PA) 8501 (Drop plate and adapters as required)	689	NO
1 Kick Plate	K1050 10" HIGH 4BE CSK	US32D	RO
1 Door Stop	409	US32D	RO
1 Gasketing	S88D (Head & Jambs)		PE

Set: 19.0

Doors: 115-1

3 Hinge	TA2714	US26D	MK
1 Office Lock	DG1 8205 LNNJ	US26D	SA
1 Door Stop	409	US32D	RO
1 Gasketing	S88D (Head & Jambs)		PE

Set: 20.0

Doors: 102A-1

6 Hinge	TA2714	US26D	MK
2 Flush Bolt	555/557	US26D	RO
1 Dust Proof Strike	570	US26D	RO
1 Passage Set	8215 LNNJ	US26D	SA
2 Surf Overhead Stop	10-336	630	RF
2 Silencer	608		RO

Set: 21.0

Doors: 408-1

3 Hinge	TA2714 NRP	US26D	MK
1 Classroom Lock	DG1 8237 LNNJ	US26D	SA

1 Surf Overhead Stop	10-336	630	RF
3 Silencer	608		RO

Set: 22.0

Doors: 103-1, 104-1, 113-1

3 Hinge	TA2714	US26D	MK
1 Privacy Set	49 8265 LNNJ	US26D	SA
1 Door Stop	409	US32D	RO
3 Silencer	608		RO

Set: 23.0

Doors: 111-1, 112-1, 115A-74, 406-1

3 Hinge (heavy weight)	T4A3786	US26D	MK
1 Push Plate	70C	US32D-MS	RO
1 Pull	RM301 Mtg-Type 12XHD	US32D-316	RO
1 Surface Closer	8501/ (PA) 8501 (Drop plate and adapters as required)	689	NO
1 Kick Plate	K1050 10" HIGH 4BE CSK	US32D	RO
1 Door Stop	409	US32D	RO
1 Gasketing	S88D (Head & Jambs)		PE

Set: 24.0

Doors: 011-1, 115A-75, 405-1

3 Hinge (heavy weight)	T4A3786	US26D	MK
1 Push Plate	70C	US32D-MS	RO
1 Pull	RM301 Mtg-Type 12XHD	US32D-316	RO
1 Surface Closer	CLP8501 (Drop plate and adapters as required)	689	NO
1 Kick Plate	K1050 10" HIGH 4BE CSK	US32D	RO
1 Gasketing	S88D (Head & Jambs)		PE

Set: 25.0

Doors: 324-1

6 Hinge	TA2714 NRP	US26D	MK
2 Flush Bolt	555/557	US26D	RO
1 Dust Proof Strike	570	US26D	RO
1 HOTEL LOCK	Hotel Lock by Security Specification	626	VI
2 Surface Closer	CPS8501 (Drop plate and adapters as required)	689	NO
2 Kick Plate	K1050 10" HIGH 4BE CSK	US32D	RO
1 Gasketing	S88D (Head & Jambs)		PE
1 Astragal	S771C x Door Height		PE

Set: 26.0

Doors: 110A-1

3 Hinge	TA2714 NRP	US26D	MK
1 HOTEL LOCK	Hotel Lock by Security Specification	626	VI
1 Surf Overhead Stop	10-336	630	RF
3 Silencer	608		RO

Set: 27.0

Doors: 322-1

3 Hinge	TA2714	US26D	MK
1 HOTEL LOCK	Hotel Lock by Security Specification	626	VI
1 Surface Closer	8501/ (PA) 8501 (Drop plate and adapters as required)	689	NO
1 Kick Plate	K1050 10" HIGH 4BE CSK	US32D	RO
1 Door Stop	409	US32D	RO
3 Silencer	608		RO

Set: 28.0

Doors: 323-1, 410-1

3 Hinge	TA2714 NRP	US26D	MK
1 HOTEL LOCK	Hotel Lock by Security Specification	626	VI
1 Surface Closer	CPS8501 (Drop plate and adapters as required)	689	NO
1 Kick Plate	K1050 10" HIGH 4BE CSK	US32D	RO
3 Silencer	608		RO

Set: 29.0

Doors: 211-1, 212-1, 321-1

3 Hinge	TA2714	US26D	MK
1 HOTEL LOCK	Hotel Lock by Security Specification	626	VI
1 Surface Closer	8501/ (PA) 8501 (Drop plate and adapters as required)	689	NO
1 Kick Plate	K1050 10" HIGH 4BE CSK	US32D	RO
1 Door Stop	409	US32D	RO
1 Gasketing	S88D (Head & Jambs)		PE

Set: 30.0

Doors: 220-1, 221-1, 221-2, 409-1

3 Hinge	TA2714 NRP	US26D	MK
1 HOTEL LOCK	Hotel Lock by Security Specification	626	VI
1 Surface Closer	CPS8501 (Drop plate and adapters as required)	689	NO
1 Kick Plate	K1050 10" HIGH 4BE CSK	US32D	RO
1 Gasketing	S88D (Head & Jambs)		PE

Set: 31.0

Doors: 319B-1

3 Hinge	MPB79	US26D	MK
1 Passage Latch	11 AU	626	YR
1 Door Stop	525	NP	RO
3 Silencer	608		RO

Notes: SILENCERS PROVIDED BY OTHERS AS NEEDED.

Set: 32.0

Doors: 201A-1, 201C-1, 202A-1, 202B-1, 203A-1, 204A-1, 205A-1, 205B-1, 206A-1, 207A-1, 208A-1, 209A-1, 210A-1, 210C-1, 211B-1, 213A-1, 213C-1, 214A-1, 215-3, 216-3, 217A-1, 218A-1, 219A-1, 301A-1, 301C-1, 302A-1, 302B-1, 303A-1, 304A-1, 305A-1, 305B-1, 306A-1, 307A-1, 308A-1, 309A-1, 310A-1, 310C-1, 311A-1, 311C-1, 312A-1, 313A-1, 314A-1, 315A-1, 316A-1, 317A-1, 318A-1, 319A-1

3 Hinge	MP79	US26D	MK
1 Privacy Lock	21 AU	626	YR
1 Door Stop	525	NP	RO
3 Silencer	608		RO

Notes: SILENCERS

Set: 33.0

Doors: 200A-1, 200B-1, 200C-1, 200D-1, 300A-1, 300B-1, 300C-1, 300F-1, 300H-1

6 Hinge	TA2714 NRP	US26D	MK
1 Flush Bolt (set)	2842/2942	US26D	RO
1 Dust Proof Strike	570	US26D	RO
1 HOTEL LOCK	Hotel Lock by Security Specification	626	VI
1 Coordinator	1600 Series x Brackets	Black	RO
2 Surface Closer	8501/ (PA) 8501 (Drop plate and adapters as required)	689	NO
2 Electromagnetic Holder	998	689	RF
1 Gasketing	S88D (Head & Jambs)		PE
1 Gasketing	ACP112BL		PE
2 Door Bottom	411APKL 36"		PE
1 Astragal	S771C x Door Height		PE

Notes: PRESENTING AUTHORIZED CREDENTIAL TO HOTEL LOCK CARD READER WILL UNLOCK TRIM ALLOWING ACCESS. EGRESS BY LEVER.
MAGNETIC HOLDER TO BE RELEASED BY FIRE ALARM ACTIVATION.

Set: 34.0

Doors: 201-1, 202-1, 203-1, 204-1, 205-1, 206-1, 207-1, 208-1, 209-1, 210-1, 213-1, 214-1, 215-1, 216-1, 217-1, 218-1, 219-1, 301-1, 302-1, 303-1, 304-1, 305-1, 306-1, 307-1, 308-1, 309-1, 310-1, 311-1, 312-1, 313-1, 314-1, 315-1, 316-1, 317-1, 318-1, 319-1

3 Hinge	TA2714	US26D	MK
1 HOTEL LOCK	Hotel Lock by Security Specification	626	VI
1 Surface Closer	1703BC COV	689	NO
1 Door Stop	409	US32D	RO
1 Gasketing	S773BL (Head & Jambs)		PE
1 Gasketing	ACP112BL		PE
1 Door Bottom	411APKL 36"		PE
1 Viewer	627	CRM	RO
1 Privacy Latch	PDL	CRM	RO

Notes: PRESENTING AUTHORIZED CREDENTIAL TO HOTEL LOCK CARD READER WILL UNLOCK TRIM ALLOWING ACCESS. EGRESS BY LEVER.

Set: 35.0

Doors: 200E-1, 300D-1

3 Hinge	TA2714 NRP	US26D	MK
1 HOTEL LOCK	Hotel Lock by Security Specification	626	VI
1 Surface Closer	8501/ (PA) 8501 (Drop plate and adapters as required)	689	NO
1 Door Stop	409	US32D	RO
1 Gasketing	S773BL (Head & Jambs)		PE
1 Gasketing	ACP112BL		PE
1 Door Bottom	411APKL 36"		PE
1 Viewer	627	CRM	RO
1 Privacy Latch	PDL	CRM	RO

Notes: PRESENTING AUTHORIZED CREDENTIAL TO HOTEL LOCK CARD READER WILL UNLOCK TRIM ALLOWING ACCESS. EGRESS BY LEVER.

Set: 36.0

Doors: 201-3, 202-2, 203-3, 204-3, 205-2, 206-3, 207-3, 208-2, 209-2, 210-3, 210B-2, 213B-2, 215A-1, 216A-1, 217-3, 218-2, 301-3, 302-2, 303-3, 304-3, 305-2, 306-3, 307-3, 308-2, 309-2, 310-3, 310C-2, 311B-2, 312-2, 313-2, 315-3, 316-3, 317-3, 318-2

6 Hinge	TA2714	US26D	MK
2 Roller Latch	910	US26D	RO
2 Single Dummy	81 AU	626	YR
2 Kick Plate	K2060SA	Calcutta Black	RO
2 Door Stop	528	NP	RO

Set: 37.0

Doors: 106-1, 106-2, 403-1

1 Concealed Closer w/ center pivot	608 (mounting as required)	689	RF
------------------------------------	----------------------------	-----	----

Notes: REMAINDER OF HARDWARE BY DOOR MANUFACTURER.

Set: 38.0

Doors: 002-2, 115A-101, 115A-104, 115A-105, 115A-106, 115A-107, 115A-52, 115A-85, 115A-86, 115A-87, 115A-88, 115A-89, 115A-90, 115A-91, 115A-92, 115A-94, 115A-95, 115A-96, 115A-97

1 Hardware	Hardware by Door Manufacturer	OT
------------	-------------------------------	----

Set: 39.0

Doors: 109-4A, 109-4D

1 Hardware	Hardware by Door Manufacturer	OT
------------	-------------------------------	----

Set: 40.0

Doors: 201-2, 203-2, 204-2, 206-2, 207-2, 214-2, 215-2, 216-2, 217-2, 301-2, 303-2, 304-2, 306-2, 307-2, 314-2, 315-2, 316-2, 317-2

1 Hardware	Hardware by Door Manufacturer	OT
------------	-------------------------------	----

END OF SECTION 087100