



NOTES

ELECTRICAL ROOMS WITH EQUIPMENT RATED 800-AMPERES OR MORE AND OVER 6 FEET (1829MM) WIDE, AND THAT CONTAIN OVERCURRENT DEVICES, SWITCHING DEVICES OR CONTROL DEVICES WITH EXIT OR EXIT ACCESS DOORS, SHALL BE EQUIPPED WITH PANIC HARDWARE OR FIRE EXIT HARDWARE. THE DOORS SHALL SWING IN THE DIRECTION OF EGRESS TRAVEL. (CBC 1010.1.10)

LEGEND

(E) BUILDINGS (N.I.C.)

FIRE APPARTUS ACCESS ROUTE W/ NO VERTICAL OVERHEAD OBSTRUCTIONS. SURFACE SHALL SUPPORT A MINIMUM IMPOSED LOAD OF 75,000 LBS.

(E) FIRE ACCESS ROAD

PROPOSED REPLACEMENT STRUCTURES

(E) FIRE HYDRANT

(N) FIRE HYDRANT

BUILDING INFORMATION

PROPERTY INFORMATION:

COUNTY ASSESSOR PARCEL NO. : 8038-006-911

NEW BUILDING INFORMATION (TICKET BOOTH - BLDG. U):

BUILDING HEIGHT: SINGLE STORY, 12'-3"

BUILDING AREA: 142 SQ. FT.

OCCUPANCY GROUP: B

CONSTRUCTION TYPE: V-B

NEW BUILDING INFORMATION (FIELD HOUSE - BLDG. VI):

BUILDING HEIGHT: SINGLE STORY, 18'-0"

BUILDING AREA: 2,122 SQ. FT.

OCCUPANCY GROUP: B, E, S-2

CONSTRUCTION TYPE: V-B SPRINKLERED

NEW BUILDING INFORMATION (FIELD HOUSE - BLDG. VII):

BUILDING HEIGHT: SINGLE STORY, 18'-0"

BUILDING AREA: 2,122 SQ. FT.

OCCUPANCY GROUP: B, E, S-1

CONSTRUCTION TYPE: V-B SPRINKLERED

ELECTRICAL ROOM \*:

BUILDING HEIGHT: SINGLE STORY, 11'-4"

BUILDING AREA: 202 SQ. FT.

OCCUPANCY GROUP: S

CONSTRUCTION TYPE: V-B

\*FIRE SPRINKLERS NOT REQUIRED

810

FIRE & LIFE SAFETY SITE CONDITIONS SUBMITTAL

School District Acceptance of Acceptable Design Alternates

By signing this form, the school district acknowledges and accepts the proposed design as an alternative to California Building Code (CBC) and California Fire Code (CFC) minimum requirements, as indicated by one or more of the conditions indicated at items 4a, 5a, 6a or 7a, for providing fire and life safety protection of life and property.

Accepted by: \_\_\_\_\_ Title: \_\_\_\_\_

Signature: \_\_\_\_\_ Date: \_\_\_\_\_

LOCAL FIRE AUTHORITY (LFA) INFORMATION

LFA Agency Name: \_\_\_\_\_

LFA Review Official: \_\_\_\_\_

Title: \_\_\_\_\_

Work E-mail: \_\_\_\_\_

COUNTY OF LOS ANGELES  
FIRE DEPARTMENT  
FIRE PREVENTION ENGINEERING

APPROVED

By M. Bravo

Fire Prevention Engineer

Date 11/25/2020

PROJECT INFORMATION

School District/Owner: Norwalk La Mirada Unified School District

Project Name/School: La Mirada High School

Project Address: 13520 Adelfa Dr, La Mirada, CA 90638

FIRE & LIFE SAFETY INFORMATION

1. Has a fire hydrant flow test been performed within the past 12 months?  
(If yes, provide a copy of the test data.) Yes ☐ No ☐

2. Was the fire hydrant water flow test performed as part of this LFA review? Yes ☐ No ☐

3. Is the project located within a designated fire hazard severity zone as established by Cal-Fire? (If yes, indicate fire hazard zone classification below)  
Refer to the following for fire hazard zone locations:  
[www.fire.ca.gov/fire\\_prevention/wildland\\_zones\\_maps](http://www.fire.ca.gov/fire_prevention/wildland_zones_maps)  
Wildland Interface Area (WIFA) (If any designations are checked, project design must meet the requirements of CBC Chapter 7A.) Moderate ☐ High ☐ Very High ☐ WIFA ☐

CONDITION MEANS AND METHODS RESOLUTION

4. Emergency vehicle access roadways do not meet CFC requirements.  
4a. Acceptable Alternate: Emergency vehicle and personnel access as proposed by the project architect is acceptable for providing fire suppression and protection of life and property.

5. Fire Hydrants: Number and spacing does not meet CFC requirements.  
5a. Acceptable Alternate: Number of fire hydrants and spacing as proposed by the project architect is acceptable for fire suppression and protection of life and property.

6. Fire Hydrants: Water flow and pressure are less than CFC minimum.

6a. Acceptable Alternate: The available flow and pressure is acceptable for providing fire suppression and protection of life and property.

7. Location of fire department connection(s) serving fire sprinkler systems or standpipe systems does not meet CFC requirements.

7a. Acceptable Alternate: The location of fire department connection serving the fire sprinkler system and/or standpipe system is acceptable for providing fire suppression and protection of life and property.

ALTERNATE ACCEPTED

Yes No N/A N/R

4.

4a.

5.

5a.

6.

6a.

7.

7a.

4.

4a.

5.

5a.

6.

6a.

7.

7a.

DSA 810 (rev 10-22-18)

DIVISION OF THE STATE ARCHITECT

DEPARTMENT OF GENERAL SERVICES

STATE OF CALIFORNIA

Page 1 of 4

DSA 810 (rev 10-22-18)

DIVISION OF THE STATE ARCHITECT

DEPARTMENT OF GENERAL SERVICES

STATE OF CALIFORNIA

Page 2 of 4

IDENTIFICATION STAMP  
DIV. OF THE STATE ARCHITECT  
APP: 03-120551 INC:  
REVIEWED FOR  
SS ☒ FLS ☒ ACS ☒  
DATE: 01/11/2021

REVISIONS

NORWALK LA MIRADA UNIFIED SCHOOL DISTRICT  
LA MIRADA HIGH SCHOOL NEW FOOTBALL  
STADIUM PROJECT  
13520 ADELEFA DRIVE, LA MIRADA, CA 90638

DSA # 03-120551

NAC  
ARCHITECTURE

NAC NO: 161-19015  
DATE: 12/10/2020

DSA BACKCHECK  
SUBMISSION

FIRE ACCESS SITE PLAN

G1.03

© 2020 NAC, INC.