



KEYNOTES - THIS SHEET ONLY

- 1 IN-GRADE FIELD COMMUNICATION BOX. SEE E3.02
- 2 EXISTING POLE MOUNTED FIXTURE TO BE REMOVED - SALVAGE AND RETURN TO DISTRICT.
- 3 INSTALL W.P. GFI 20-AMP, 120V DUPLEX RECEPTACLE IN "POWER" SIDE OF FIELD COMMUNICATION BOX AND CONNECT TO CIRCUIT AS INDICATED. SEE E3.02
- 4 MOUNT ON REAR SIDE OF PRESS BOX - SEE SHEET E10.01. VERIFY EXACT LOCATION OF PANEL WITH PRESS BOX INSTALLER.
- 5 MOUNT ON "RISER BOARD" AT FRONT EDGE OF BLEACHERS. COORDINATE EXACT LOCATION & MOUNTING WITH BLEACHER INSTALLER. MOUNT RECEPTACLE IN A LOCKABLE NEMA 3R ENCLOSURE. COORDINATE WITH SIGNAL PLAN FOR MOUNTING OF THE DATA JACK AND MICROPHONE JACK IN THE SAME ENCLOSURE.
- 6 CIRCUIT FOR EXTERIOR LIGHTING SHALL BE CONNECTED TO A NEW RELAY MOUNTED ADJACENT TO THE PANEL. NEW RELAY SHALL BE CONTROLLED BY THE "AUTOMATED LOGIC CORPORATION" CONTROL SYSTEM.

EXISTING UNDERGROUND ELECTRICAL UTILITIES NOTES

1. IN ALL AREAS WHERE EXCAVATION OCCURS, EITHER FOR DEMOLITION OR NEW CONSTRUCTIONS, THE CONTRACTOR SHALL THOROUGHLY INVESTIGATE UNDERGROUND ELECTRICAL UTILITIES (POWER, SIGNAL, FIRE ALARM, ETC.) PRIOR TO ANY EXCAVATION.
2. THE DEPTH OF THE EXISTING UTILITY SHALL BE NOTED AND COORDINATED WITH THE NEW EXCAVATION/CONSTRUCTION TO DETERMINE IF THE DEPTH OF THE UTILITY WILL REMAIN IN COMPLIANCE WITH THE C.E.C.
3. THE CONTRACTOR SHALL NOTIFY THE DISTRICT, ARCHITECT, AND ENGINEER IF THE EXISTING UTILITY BECOMES A CONFLICT. NO EXCAVATION SHALL TAKE PLACE UNTIL AN ACCEPTABLE RESOLUTION HAS BEEN DETERMINED AND A COURSE OF ACTION DECIDED.

PARTIAL SITE PLAN - ELECTRICAL

SCALE: 1" = 20'-0"



IDENTIFICATION STAMP
DIV. OF THE STATE ARCHITECT
APP: 03-120551 INC:
REVIEWED FOR
SS ☒ FLS ☒ ACS ☒
DATE: 01/11/2021

REVISIONS



1909B.MOD
TURPIN & RATTAN
ENGINEERING, INC.
CONSULTING ENGINEERS
10000 RAVENHILL BLVD., SUITE 200
MONTREMO, CA 91020-1855
818 / 249 / 0444 FAX 818 / 249 / 1487

NORWALK LA MIRADA UNIFIED SCHOOL DISTRICT
LA MIRADA HIGH SCHOOL NEW FOOTBALL
STADIUM PROJECT
13520 ADELFA DRIVE, LA MIRADA, CA 90638

DSA # 03-120551

NAC
ARCHITECTURE

NAC NO. 161-19015
DATE 08-26-2020

DSA BACKCHECK
SUBMISSION

PARTIAL
SITE PLAN -
ELECTRICAL

E6.02