

May 20, 2024

Adrian Escamilla
City of Ontario
1333 S Bon View Avenue
Ontario, California 91761
aescamilla@ontarioca.gov

Subject: Hazardous Building Materials Survey for 2500 S Archibald Avenue, Ontario

Dear Adrian Escamilla:

Attached please find the revised report for the asbestos and lead survey report for the project site at 2500 S Archibald Avenue in Ontario, California (site). There is one building at the site, which is occupied by the police department. Per the proposal, asbestos and lead sampling was conducted in eight areas/rooms in the police department building.

Aurora Industrial Hygiene (Aurora) conducted the survey on April 30, 2024. Each of the rooms/areas were inspected for asbestos-containing materials (ACM) and lead-based paint (LBP). ACM was not detected in any of the materials sampled. LBP (defined by the federal government as paint with lead at concentrations greater than 1.0 mg/cm²) was not detected in any painted surfaces or building materials. Lower concentrations of lead were detected in 8 (of 38) samples on concrete floors, walls, and door frames. The report includes recommendations for occupants, construction/maintenance worker protections, and handling and disposal related to lead.

We appreciate this opportunity to assist you. If you have any questions, please contact me at gcmahon@dudek.com or 760.479.4130.

Sincerely,



Glenna McMahon, PE
Principal Engineer

att: Asbestos and Lead Sampling Report, Aurora Industrial Hygiene



May 16, 2024

Glenna McMahon
Principal, Hdro/Haz
Dudek
gcmahon@dudek.com

Re: Asbestos and Lead Sampling– 2500 S. Archibald Avenue, Ontario

Dear Glenna McMahon:

This report documents the findings from an asbestos and lead inspection conducted by Aurora Industrial Hygiene, Inc. (Aurora) at the Ontario Police Department building located at 2500 South Archiblad Avenue in Ontario, California on April 30, 2024. The purpose of the survey was to collect samples of specific building materials for asbestos and lead, as requested.

Certified Asbestos Consultant (#03-3374) and Department of Public Health certified lead Inspector/Assessor (#LRC-00002723) Robert Rinck and Department of Public Health certified lead Sampling Technician (#LRC-00011237) Blaine Robey conducted the assessment on April 30, 2024. All data was reviewed and the report signed by Certified Industrial Hygienist (CIH #6662), CAC(93-0919), CDPH Inspector/Risk Assessor Grace M. Rinck. Robert Rinck, Blaine Robey, and Grace Rinck work for Aurora Industrial Hygiene located at 2667 East 28th Street, Suite 512 in Signal Hill, California 90755, (626) 403-4104.

Executive Summary

Lead based paint (greater that 1.0 mg/cm²) was not detected in any painted surfaces or building materials tested. Lead was detected in lower concentrations on concrete floors and walls and door frames. Asbestos was not detected in any of the materials sampled. Results and recommendations are provided in this report.

Asbestos Sampling

Seventy-eight (78) bulk samples of suspect asbestos containing materials were collected. The collected samples for asbestos were assigned a unique sample identification number, placed in sealed containers, labeled, and delivered under proper chain of custody protocol to Eurofins EPK Built Environmental Testing LLC, located at 931 Corporate Center Drive in Pomona, CA 91768 (NVLAB #600282-0), (800) 651-4802. The samples were collected following the provision of 40 CFR Part 763.86. The samples were analyzed as required in South Coast Air Quality Management District (SCAQMD) Rule 1403 by the method specified in Appendix A, Subpart F, 40 CRF Part 763, Polarized Light Microscopy (PLM) for Asbestos via EPA Method 600/R-93/116 “Method for Determination of Asbestos in Bulk Building Materials”.

Lead Sampling

A lead-based paint inspection was conducted on various surfaces in the restroom using a portable x-ray fluorescence (XRF) spectrum analyzer Viken Pb200i, (serial number 2721). XRF readings were taken using the “Unlimited” mode of the Viken. No substrate correction is required for testing using the “Unlimited” mode.

XRF readings were made on representative substrates. Testing combinations were tested non-destructively by holding the Viken against the surface being tested. At each XRF sample location the Viken shutter is opened, and one reading was made.

To ensure that the XRF was working properly various quality control tests were performed before, during and after the on-site work.

A reading of >1 mg/cm² was considered positive for lead-based paint, in accordance with Chapter 7 (revised, 1997) of the Housing and Urban Development Guidelines for Lead Based Paint Inspection.

Laboratory Results:

Asbestos Sampling Results

Sample #	Material	Location	Cond.	F/NF	Amount	Result
29083-01	Concrete	Armory Room slab floor	Good	NF	4200 SF	None Detected
29083-02	Concrete		Good	NF		None Detected
29083-03	Concrete		Good	NF		None Detected
29083-04	CMU mortar	Armory Room N, W walls	Good	NF	2600 SF	None Detected
29083-05	CMU mortar		Good	NF		None Detected
29083-06	CMU mortar		Good	NF		None Detected
29083-07	Carpet glue	TI Room floor	Good	NF	1120 SF	None Detected
29083-08	Carpet glue		Good	NF		None Detected
29083-09	Carpet glue		Good	NF		None Detected
29083-10	Vinyl floor tile, beige	TI Room 3302, under carpet	Good	NF	392 SF	None Detected
29083-10	Floor tile mastic, yellow		Good	NF		None Detected
29083-11	Vinyl floor tile, beige		Good	NF		None Detected
29083-11	Floor tile mastic, yellow		Good	NF		None Detected
29083-12	Vinyl floor tile, beige		Good	NF		None Detected
29083-12	Floor tile mastic, yellow		Good	NF		None Detected
29083-13	Baseboard mastic	TI Room	Good	NF	Throughout	None Detected
29083-14	Baseboard mastic		Good	NF		None Detected
29083-15	Baseboard mastic		Good	NF		None Detected
29083-16	Drywall	TI Room walls	Good	NF	Throughout	None Detected

Sample #	Material	Location	Cond.	F/NF	Amount	Result
29083-16	Joint compound		Good	NF		None Detected
29083-17	Drywall		Good	NF		None Detected
29083-17	Joint compound		Good	NF		None Detected
29083-18	Drywall		Good	NF		None Detected
29083-18	Joint compound		Good	NF		None Detected
29083-19	2x4 Ceiling tile	TI Room ceilings	Good	NF	1120 SF	None Detected
29083-20	2x4 Ceiling tile		Good	NF		None Detected
29083-21	2x4 Ceiling tile		Good	NF		None Detected
29083-22	CMU mortar	TI Room W, S walls	Good	NF	1200 SF	None Detected
29083-23	CMU mortar		Good	NF		None Detected
29083-24	CMU mortar		Good	NF		None Detected
29083-25	12x12 Vinyl floor tile, gray	Open Shell Room #2	Good	NF	506 SF	None Detected
29083-25	Floor tile mastic, black		Good	NF		None Detected
29083-26	12x12 Vinyl floor tile, gray		Good	NF		None Detected
29083-26	Floor tile mastic, black		Good	NF		None Detected
29083-27	12x12 Vinyl floor tile, gray		Good	NF		None Detected
29083-27	Floor tile mastic, black		Good	NF		None Detected
29083-28	Drywall	Open Shell Room #2 walls	Good	NF	1440 SF	None Detected
29083-28	Joint compound		Good	NF		None Detected
29083-29	Drywall		Good	NF		None Detected
29083-29	Joint compound		Good	NF		None Detected
29083-30	Drywall		Good	NF		None Detected
29083-30	Joint compound		Good	NF		None Detected
29083-31	Baseboard mastic	Open Shell Room #2	Good	NF	90 LF	None Detected
29083-32	Baseboard mastic		Good	NF		None Detected
29083-33	Baseboard mastic		Good	NF		None Detected
29083-34	Terrazzo	Open Shell Room #1 floor	Good	NF	2700 SF	None Detected
29083-35	Terrazzo		Good	NF		None Detected
29083-36	Terrazzo		Good	NF		None Detected
29083-37	Terrazzo seal w/grout	Open Shell Room #1 floor	Good	NF	2700 SF	None Detected
29083-38	Terrazzo seal w/grout		Good	NF		None Detected
29083-39	Terrazzo seal w/grout		Good	NF		None Detected
29083-40	Concrete	Open Shell Room #1 slab	Good	NF	2700 SF	None Detected
29083-41	Concrete		Good	NF		None Detected
29083-42	Concrete		Good	NF		None Detected
29083-43	Baseboard mastic	Open Shell Room #1	Good	NF	2700 SF	None Detected
29083-44	Baseboard mastic		Good	NF		None Detected

Sample #	Material	Location	Cond.	F/NF	Amount	Result
29083-45	Baseboard mastic		Good	NF		None Detected
29083-46	Drywall	Open Shell Room #1 walls	Good	NF	1800 SF	None Detected
29083-46	Joint compound		Good	NF		None Detected
29083-47	Drywall		Good	NF		None Detected
29083-47	Joint compound		Good	NF		None Detected
29083-48	Drywall		Good	NF		None Detected
29083-48	Joint compound		Good	NF		None Detected
29083-49	Carpet glue	Office-Storage #1	Good	NF	368 SF	None Detected
29083-50	Carpet glue		Good	NF		None Detected
29083-51	Carpet glue		Good	NF		None Detected
29083-52	Baseboard mastic	Office-Storage #1	Good	NF	78 LF	None Detected
29083-53	Baseboard mastic		Good	NF		None Detected
29083-54	Baseboard mastic		Good	NF		None Detected
29083-55	Vinyl floor tile, beige	Office-Storage #1, under carpet	Good	NF	368 SF	None Detected
29083-55	Floor tile mastic, black		Good	NF		None Detected
29083-56	Vinyl floor tile, beige		Good	NF		None Detected
29083-56	Floor tile mastic, black		Good	NF		None Detected
29083-57	Vinyl floor tile, beige		Good	NF		None Detected
29083-57	Floor tile mastic, black		Good	NF		None Detected
29083-58	Carpet glue	Polygraph Rooms 1813, 1814	Good	NF	280 SF	None Detected
29083-59	Carpet glue		Good	NF		None Detected
29083-60	Carpet glue		Good	NF		None Detected
29083-61	Baseboard mastic	Polygraph Rooms 1813, 1814	Good	NF	96 LF	None Detected
29083-62	Baseboard mastic		Good	NF		None Detected
29083-63	Baseboard mastic		Good	NF		None Detected
29083-64	Vinyl floor tile, beige	Polygraph Rooms under carpet	Good	NF	280 SF	None Detected
29083-64	Floor tile mastic, black		Good	NF		None Detected
29083-65	Vinyl floor tile, beige		Good	NF		None Detected
29083-65	Floor tile mastic, black		Good	NF		None Detected
29083-66	Vinyl floor tile, beige		Good	NF		None Detected
29083-66	Floor tile mastic, black		Good	NF		None Detected
29083-67	Carpet glue	Patrol Sargent's Room	Good	NF	1150 SF	None Detected
29083-68	Carpet glue		Good	NF		None Detected
29083-69	Carpet glue		Good	NF		None Detected
29083-70	Baseboard mastic	Patrol Sargent's Room	Good	NF	232 LF	None Detected
29083-71	Baseboard mastic		Good	NF		None Detected
29083-72	Baseboard mastic		Good	NF		None Detected

Sample #	Material	Location	Cond.	F/NF	Amount	Result
29083-73	Ceramic tile grout	Janitorial Room	Good	NF	1140 SF	None Detected
29083-74	Ceramic tile grout		Good	NF		None Detected
29083-75	Ceramic tile grout		Good	NF		None Detected
29083-76	Wall mastic	Janitorial Room	Good	NF	240 SF	None Detected
29083-77	Wall mastic		Good	NF		None Detected
29083-78	Wall mastic		Good	NF		None Detected

Cond. = Condition F/NF = Friable/Non-friable

Lead XRF Results

Test #	Area	Side	Component	Substrate	Color	Cond.	Result (mg/cm ²)
1	Armory Room	A	Wall	Concrete	Gray	Intact	0
2	Armory Room	B	Wall	Drywall	Gray	Intact	0
3	Armory Room	B	Door	Metal	Dark gray	Intact	0
4	Armory Room	B	Doorframe	Metal	Dark gray	Intact	0
5	Armory Room	N/A	Floor	Concrete	Clear	Intact	0.3
6	Armory Room	N/A	Floor	Concrete	Dark gray	Intact	0.3
7	Armory Room	A	Wall panel	Wood	White	Intact	0
8	Armory Room	D	I-beam	Metal	Gray	Intact	0
9	TI - warehouse	A	Wall	Drywall	White	Intact	0
10	TI - warehouse	B	Doorframe	Metal	White	Intact	0
11	TI - Copy room	B	Wall	Concrete	White	Intact	0
12	TI - Copy room	B	Doorframe	Metal	White	Intact	0
13	TI - 3302	D	Wall	Drywall	Silver	Intact	0
14	TI - 3302	C	Doorframe	Metal	White	Intact	0.3
15	TI - 4502	A	Wall	Drywall	Silver	Intact	0
16	TI - 4502	A	Doorframe	Metal	White	Intact	0.2
17	TI - 4503	A	Wall	Drywall	White	Intact	0
18	TI - 4503	C	Doorframe	Metal	White	Intact	0
19	TI - 4505	C	Wall	Concrete	White	Intact	0.3
20	TI - 4505	C	Bay doorframe	Metal	Black	Intact	0
21	Open Shell #2	C	Wall	Drywall	White	Intact	0
22	Open Shell #2	C	Doorframe	Metal	White	Intact	0
23	Open Shell #1	B	Wall	Concrete	White	Intact	0.3
24	Open Shell #1	A	Doorframe	Metal	White	Intact	0
25	Open Shell #1	N/A	Floor	Terrazzo	Tan	Intact	0
26	Open Shell #1	N/A	Support pole	Metal	Tan	Intact	0.2

Test #	Area	Side	Component	Substrate	Color	Cond.	Result (mg/cm ²)
27	Office Storage #1	C	Wall	Drywall	White	Intact	0
28	Office Storage #1	D	Wall	Drywall	Blue	Intact	0
29	Office Storage #1	D	Window frame	Metal	White	Intact	0
30	Office Storage #1	D	Doorframe	Metal	White	Intact	0
31	Polygraph 1814	D	Doorframe	Metal	White	Intact	0
32	Polygraph 1813	D	Doorframe	Metal	White	Intact	0
33	Patrol Sargent's Room	B	Wall	Drywall	White	Intact	0
34	Patrol Sargent's Room	A	Wall	Drywall	Blue	Intact	0
35	Patrol Sargent's Room	C	Doorframe	Metal	White	Intact	0
36	Janitorial Room	D	I-beam	Metal	Red	Intact	0
37	Janitorial Room	D	Doorframe	Metal	White	Intact	0.5
38	Janitorial Room	N/A	Floor tile	Ceramic	Red	Intact	0

Location	Identifies the room or area.
Side	“A” side is facing the main entrance of the building. Location’s “B”, “C”, and “D” follow in a clockwise direction
Component	Identifies the actual component tested.
Substrate	The material of the tested component.
Color	The visible color of the upper coatings.
Condition	The condition of the paint was determined, as defined in the <i>Guidelines for the Evaluation and Control of Lead-Based Paint Hazards in Housing</i> : Intact – the entire surface is intact., Fair – less than or equal to ten percent of the total surface area of the component is deteriorated. Poor – more than ten percent of the total surface area of the component is deteriorated.
Rep	Identifies the number or amount of a component or surface.

Discussion and Recommendations

Asbestos

Asbestos was not detected in any of the materials sampled.

The California Environmental Protection Agency (Cal/EPA) defines asbestos containing material (ACM) as containing asbestos in an amount greater or equal than 1%. The local enforcement agency for Cal/EPA is the South Coast Air Quality District (SCAQMD). California OSHA (Cal/OSHA) has determined that building materials containing asbestos at “trace” levels can still pose a health risk and thus regulates asbestos materials containing greater than 0.1% asbestos (ACCM).

CalOSHA 8CCR1529, 8CCR 5208 and all other applicable federal, state, and local regulations regarding the maintenance, removal, transport and disposal of ACM should be applied. Notification to SCAQMD whenever 100 square feet or linear feet of ACM or more will be disturbed is also required.

Lead

Lead Based Paint (LBP) and Lead Containing Building Components were not detected.

Lead was detected at lower concentrations on some concrete floors/walls and door frames.

We recommend that hazard communication training and exposure assessments be conducted for employees who may be exposed to lead. The contractor must have, at a minimum, completed and satisfied the Cal/OSHA lead training requirement prior to disturbance. In addition, there is a contractor notification requirement for Cal/OSHA for projects that disturb greater than 100 SF of LBP (>1 mg/cm²).

Worker Protection

California regulations (8 CCR 1532.1) define lead-related construction work as, “Construction, alteration, painting, demolition, salvage, renovation, repair, or maintenance of any residential, public or commercial building, including preparation and clean-up, that, by using or disturbing lead containing material or soil, may result in significant exposure of individuals to lead”. As such, Cal/OSHA does not distinguish between LBP and paint, which contains lead at a lower concentration. The presence of lead at any level requires that exposure assessments be conducted and the provisions of 8 CCR 1532.1 be followed, including but not limited to training, notification, medical evaluations, and personal protective equipment. Objective data confirming that materials or surface coatings containing less than 0.06% (600 ppm) of lead may be used to demonstrate that employee exposure will not exceed the AL (action level), as long as every unique surface or material has been sampled or analyzed.

Handling/Disposal

If paint is chipping or peeling from its substrate, the damaged paint should be cleaned from the substrate and this waste tested as described below. Prior to any demolition or remodeling activities, the substrate/attached paint should also be tested as described below.

A composite sample should be analyzed for Total Threshold Limit Concentration (TTLC) by USEPA reference method SW846. If the concentration of lead is greater than 1000 mg/kg the sample must be disposed of by a landfill which can handle such wastes. If the concentration is less than 50 mg/kg the sample may be disposed of as construction debris, if it is to remain in California. If the result falls between 50 mg/kg and 1000 mg/kg, the sample must be further analyzed by the Waste Extraction Test (WET) for Soluble Threshold Limit Concentration (STLC) as described in 22 CCR 66261.24a. If this concentration exceeds 5 mg/liter the sample must be handled and disposed of as hazardous waste.

Outside of California

All lead-containing paint which may be disposed of outside the State of California must be tested for Toxicity Characteristic Leaching Procedure (TCLP) regardless of whether it is essentially intact. The sample may be a composite of the paint and the substrate if the paint is intact. Any material with results exceeding 5 mg/l must be treated as hazardous waste.

Limitations


This report is based solely upon the condition of the property on the dates of the inspection. Aurora has performed this work, made the findings, and proposed the recommendations described in this report in accordance with generally accepted industrial hygiene practices in effect at the time the work was performed. No warranties, express or implied, are made by Aurora as to the use of any information disclosed in this report.

I hope that this information is helpful. A sample location diagram, pictures, laboratory results and inspector certifications are attached.

I hope this information is helpful. Please contact us at (626) 403-4104 should there be any questions.

Sincerely,

AURORA INDUSTRIAL HYGIENE, INC.



Grace M. Rinck, CIH, CAC, CDPH Lead Certified Inspector/Risk Assessor

Attachments: Diagram, Laboratory Analysis, Certifications, 8552 Form

Location Diagram



Laboratory Analysis

Report for:

Mr. Robert Rinck
Aurora Industrial Hygiene, Inc.
2667 East 28th Street, Suite 512
Signal Hill, CA 90755

Regarding: Eurofins EPK Built Environment Testing, LLC
Project: 29083; Ontario
EML ID: 3628215

Approved by:



Approved Signatory
Dr. Ami Modha

Dates of Analysis:

Asbestos PLM: 05-02-2024 and 05-03-2024

Service SOPs: Asbestos PLM (EPA 40CFR App E to Sub E of Part 763 & EPA METHOD 600/R-93-116, SOP EM-AS-S-1267)
NVLAP Lab Code 600282-0

All samples were received in acceptable condition unless noted in the Report Comments portion in the body of the report. The results relate only to the samples as received and tested. The results include an inherent uncertainty of measurement associated with estimating percentages by polarized light microscopy. Measurement uncertainty data for sample results with >1% asbestos concentration can be provided when requested.

Eurofins EPK Built Environment Testing, LLC ("the Company"), a member of the Eurofins Built Environment Testing group of companies, shall have no liability to the client or the client's customer with respect to decisions or recommendations made, actions taken or courses of conduct implemented by either the client or the client's customer as a result of or based upon the Test Results. In no event shall the Company be liable to the client with respect to the Test Results except for the Company's own willful misconduct or gross negligence nor shall the Company be liable for incidental or consequential damages or lost profits or revenues to the fullest extent such liability may be disclaimed by law, even if the Company has been advised of the possibility of such damages, lost profits or lost revenues. In no event shall the Company's liability with respect to the Test Results exceed the amount paid to the Company by the client therefor.

Client: Aurora Industrial Hygiene, Inc.
 C/O: Mr. Robert Rinck
 Re: 29083; Ontario

Date of Sampling: 04-30-2024
 Date of Receipt: 05-01-2024
 Date of Report: 05-03-2024

ASBESTOS PLM REPORT

Total Samples Submitted: 78
Total Samples Analyzed: 78
Total Samples with Layer Asbestos Content > 1%: 0

Location: 29083-01, Concrete

Lab ID-Version‡: 17757997-1

Sample Layers	Asbestos Content
Gray Concrete	ND
Sample Composite Homogeneity: Moderate	

Location: 29083-02, Concrete

Lab ID-Version‡: 17757998-1

Sample Layers	Asbestos Content
Gray Concrete	ND
Sample Composite Homogeneity: Moderate	

Location: 29083-03, Concrete

Lab ID-Version‡: 17757999-1

Sample Layers	Asbestos Content
Gray Concrete	ND
Sample Composite Homogeneity: Moderate	

Location: 29083-04, Mortar

Lab ID-Version‡: 17758000-1

Sample Layers	Asbestos Content
Gray Mortar with Paint	ND
Sample Composite Homogeneity: Moderate	

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the federal government. The Company reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Aurora Industrial Hygiene, Inc.
 C/O: Mr. Robert Rinck
 Re: 29083; Ontario

Date of Sampling: 04-30-2024
 Date of Receipt: 05-01-2024
 Date of Report: 05-03-2024

ASBESTOS PLM REPORT

Location: 29083-05, Mortar

Lab ID-Version‡: 17758001-1

Sample Layers	Asbestos Content
Gray Mortar with Paint	ND
Sample Composite Homogeneity: Moderate	

Location: 29083-06, Mortar

Lab ID-Version‡: 17758002-1

Sample Layers	Asbestos Content
Gray Mortar with Paint	ND
Sample Composite Homogeneity: Moderate	

Location: 29083-07, Carpet glue

Lab ID-Version‡: 17758003-1

Sample Layers	Asbestos Content
Gray Glue	ND
Gray Carpet	ND
Composite Non-Asbestos Content:	60% Synthetic Fibers
Sample Composite Homogeneity: Moderate	

Location: 29083-08, Carpet glue

Lab ID-Version‡: 17758004-1

Sample Layers	Asbestos Content
White Glue	ND
Blue Carpet	ND
Composite Non-Asbestos Content:	60% Synthetic Fibers
Sample Composite Homogeneity: Moderate	

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the federal government. The Company reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by -"x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Aurora Industrial Hygiene, Inc.
 C/O: Mr. Robert Rinck
 Re: 29083; Ontario

Date of Sampling: 04-30-2024
 Date of Receipt: 05-01-2024
 Date of Report: 05-03-2024

ASBESTOS PLM REPORT

Location: 29083-09, Carpet glue

Lab ID-Version‡: 17758005-1

Sample Layers	Asbestos Content
White Glue	ND
Blue Carpet	ND
Composite Non-Asbestos Content:	60% Synthetic Fibers
Sample Composite Homogeneity:	Moderate

Location: 29083-10, VFT with mastic

Lab ID-Version‡: 17758006-1

Sample Layers	Asbestos Content
Yellow Mastic (Trace)	ND
Beige Floor Tile	ND
Sample Composite Homogeneity:	Moderate

Location: 29083-11, VFT with mastic

Lab ID-Version‡: 17758007-1

Sample Layers	Asbestos Content
Yellow Mastic (Trace)	ND
Beige Floor Tile	ND
Sample Composite Homogeneity:	Moderate

Location: 29083-12, VFT with mastic

Lab ID-Version‡: 17758008-1

Sample Layers	Asbestos Content
Yellow Mastic (Trace)	ND
Beige Floor Tile	ND
Sample Composite Homogeneity:	Moderate

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the federal government. The Company reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Aurora Industrial Hygiene, Inc.
 C/O: Mr. Robert Rinck
 Re: 29083; Ontario

Date of Sampling: 04-30-2024
 Date of Receipt: 05-01-2024
 Date of Report: 05-03-2024

ASBESTOS PLM REPORT

Location: 29083-13, BB mastic

Lab ID-Version‡: 17758009-1

Sample Layers	Asbestos Content
Off-White Mastic with White Joint Compound	ND
Gray Cove Base	ND
Sample Composite Homogeneity: Moderate	

Comments: Some layers in the sample were inseparable without cross contamination.

Location: 29083-14, BB mastic

Lab ID-Version‡: 17758011-1

Sample Layers	Asbestos Content
Off-White Mastic with Brown Paper and Paint	ND
Gray Cove Base	ND
Composite Non-Asbestos Content: 5% Cellulose	
Sample Composite Homogeneity: Moderate	

Comments: Some layers in the sample were inseparable without cross contamination.

Location: 29083-15, BB mastic

Lab ID-Version‡: 17758011-1

Sample Layers	Asbestos Content
White Joint Compound with Brown Paper	ND
Off-White Mastic	ND
Gray Cove Base	ND
Composite Non-Asbestos Content: 5% Cellulose	
Sample Composite Homogeneity: Moderate	

Comments: Some layers in the sample were inseparable without cross contamination.

Location: 29083-16, DW/JC

Lab ID-Version‡: 17758012-1

Sample Layers	Asbestos Content
White Drywall with Brown Paper	ND
White Joint Compound	ND
Cream Tape	ND
White Joint Compound with Paint	ND
Composite Non-Asbestos Content: 10% Cellulose	
Sample Composite Homogeneity: Poor	

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the federal government. The Company reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by -"x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Aurora Industrial Hygiene, Inc.
 C/O: Mr. Robert Rinck
 Re: 29083; Ontario

Date of Sampling: 04-30-2024
 Date of Receipt: 05-01-2024
 Date of Report: 05-03-2024

ASBESTOS PLM REPORT

Location: 29083-17, DW/JC

Lab ID-Version‡: 17758013-1

Sample Layers	Asbestos Content
White Drywall with Brown Paper	ND
White Joint Compound	ND
Cream Tape	ND
White Joint Compound with Paint	ND
Composite Non-Asbestos Content:	10% Cellulose
Sample Composite Homogeneity:	Poor

Location: 29083-18, DW/JC

Lab ID-Version‡: 17758014-1

Sample Layers	Asbestos Content
White Drywall with Brown Paper and Paint	ND
Composite Non-Asbestos Content:	5% Cellulose
Sample Composite Homogeneity:	Poor

Comments: Joint compound was not detected.

Location: 29083-19, 2x4 CT

Lab ID-Version‡: 17758015-1

Sample Layers	Asbestos Content
Gray Ceiling Tile with White Surface	ND
Composite Non-Asbestos Content:	45% Cellulose 5% Glass Fibers
Sample Composite Homogeneity:	Moderate

Location: 29083-20, 2x4 CT

Lab ID-Version‡: 17758016-1

Sample Layers	Asbestos Content
Gray Ceiling Tile with White Surface	ND
Composite Non-Asbestos Content:	45% Cellulose 5% Glass Fibers
Sample Composite Homogeneity:	Moderate

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the federal government. The Company reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Aurora Industrial Hygiene, Inc.
 C/O: Mr. Robert Rinck
 Re: 29083; Ontario

Date of Sampling: 04-30-2024
 Date of Receipt: 05-01-2024
 Date of Report: 05-03-2024

ASBESTOS PLM REPORT

Location: 29083-21, 2x4 CT

Lab ID-Version‡: 17758017-1

Sample Layers	Asbestos Content
Gray Ceiling Tile with White Surface	ND
Composite Non-Asbestos Content:	45% Cellulose 5% Glass Fibers
Sample Composite Homogeneity:	Moderate

Location: 29083-22, Mortar

Lab ID-Version‡: 17758018-1

Sample Layers	Asbestos Content
Beige Mortar with Paint	ND
Gray Mortar	ND
Sample Composite Homogeneity:	Moderate

Location: 29083-23, Mortar

Lab ID-Version‡: 17758019-1

Sample Layers	Asbestos Content
Beige Mortar with Paint	ND
Gray Mortar	ND
Sample Composite Homogeneity:	Moderate

Location: 29083-24, Mortar

Lab ID-Version‡: 17758020-1

Sample Layers	Asbestos Content
Beige Mortar with Paint	ND
Gray Mortar	ND
Sample Composite Homogeneity:	Moderate

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the federal government. The Company reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Aurora Industrial Hygiene, Inc.
 C/O: Mr. Robert Rinck
 Re: 29083; Ontario

Date of Sampling: 04-30-2024
 Date of Receipt: 05-01-2024
 Date of Report: 05-03-2024

ASBESTOS PLM REPORT

Location: 29083-25, 12x12 VFT with mastic

Lab ID-Version‡: 17758021-1

Sample Layers	Asbestos Content
Gray Floor Tile	ND
Black Mastic	ND
Sample Composite Homogeneity: Moderate	

Location: 29083-26, 12x12 VFT with mastic

Lab ID-Version‡: 17758022-1

Sample Layers	Asbestos Content
Gray Floor Tile	ND
Black Mastic	ND
Sample Composite Homogeneity: Moderate	

Location: 29083-27, 12x12 VFT with mastic

Lab ID-Version‡: 17758023-1

Sample Layers	Asbestos Content
Gray Floor Tile	ND
Black Mastic	ND
Sample Composite Homogeneity: Moderate	

Location: 29083-28, DW/JC

Lab ID-Version‡: 17758024-1

Sample Layers	Asbestos Content
White Joint Compound with Paint	ND
Cream Tape	ND
White Joint Compound	ND
White Drywall with Brown Paper	ND
Composite Non-Asbestos Content:	10% Cellulose
Sample Composite Homogeneity:	Poor

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the federal government. The Company reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Aurora Industrial Hygiene, Inc.
 C/O: Mr. Robert Rinck
 Re: 29083; Ontario

Date of Sampling: 04-30-2024
 Date of Receipt: 05-01-2024
 Date of Report: 05-03-2024

ASBESTOS PLM REPORT

Location: 29083-29, DW/JC

Lab ID-Version‡: 17758025-1

Sample Layers	Asbestos Content
White Joint Compound with Paint	ND
Cream Tape	ND
White Joint Compound	ND
White Drywall with Brown Paper	ND
Composite Non-Asbestos Content:	10% Cellulose
Sample Composite Homogeneity:	Poor

Location: 29083-30, DW/JC

Lab ID-Version‡: 17758026-1

Sample Layers	Asbestos Content
White Joint Compound with Paint	ND
Cream Tape	ND
White Joint Compound	ND
White Drywall with Brown Paper	ND
Composite Non-Asbestos Content:	10% Cellulose
Sample Composite Homogeneity:	Poor

Location: 29083-31, BB mastic

Lab ID-Version‡: 17758027-1

Sample Layers	Asbestos Content
White Joint Compound	ND
Off-White Mastic	ND
Gray Cove Base	ND
Sample Composite Homogeneity:	Moderate

Location: 29083-32, BB mastic

Lab ID-Version‡: 17758028-1

Sample Layers	Asbestos Content
White Joint Compound	ND
Off-White Mastic	ND
Gray Cove Base	ND
Sample Composite Homogeneity:	Moderate

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the federal government. The Company reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by -"x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Aurora Industrial Hygiene, Inc.
 C/O: Mr. Robert Rinck
 Re: 29083; Ontario

Date of Sampling: 04-30-2024
 Date of Receipt: 05-01-2024
 Date of Report: 05-03-2024

ASBESTOS PLM REPORT

Location: 29083-33, BB mastic

Lab ID-Version‡: 17758029-1

Sample Layers	Asbestos Content
White Joint Compound	ND
Off-White Mastic	ND
Gray Cove Base	ND
Sample Composite Homogeneity: Moderate	

Location: 29083-34, Terrazzo

Lab ID-Version‡: 17758030-1

Sample Layers	Asbestos Content
Peach Cementitious Material	ND
Sample Composite Homogeneity: Moderate	

Location: 29083-35, Terrazzo

Lab ID-Version‡: 17758031-1

Sample Layers	Asbestos Content
Peach Cementitious Material	ND
Sample Composite Homogeneity: Moderate	

Location: 29083-36, Terrazzo

Lab ID-Version‡: 17758032-1

Sample Layers	Asbestos Content
Peach Cementitious Material	ND
Sample Composite Homogeneity: Moderate	

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the federal government. The Company reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Aurora Industrial Hygiene, Inc.
 C/O: Mr. Robert Rinck
 Re: 29083; Ontario

Date of Sampling: 04-30-2024
 Date of Receipt: 05-01-2024
 Date of Report: 05-03-2024

ASBESTOS PLM REPORT

Location: 29083-37, Seal/grout

Lab ID-Version‡: 17758033-1

Sample Layers	Asbestos Content
Beige Sealant	ND
White Grout	ND
Sample Composite Homogeneity: Moderate	

Location: 29083-38, Seal/grout

Lab ID-Version‡: 17758034-1

Sample Layers	Asbestos Content
Beige Sealant	ND
White Grout	ND
Sample Composite Homogeneity: Moderate	

Location: 29083-39, Seal/grout

Lab ID-Version‡: 17758035-1

Sample Layers	Asbestos Content
White Grout	ND
Beige Sealant	ND
Sample Composite Homogeneity: Moderate	

Location: 29083-40, Concrete

Lab ID-Version‡: 17758036-1

Sample Layers	Asbestos Content
Gray Concrete	ND
Sample Composite Homogeneity: Moderate	

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the federal government. The Company reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Aurora Industrial Hygiene, Inc.
 C/O: Mr. Robert Rinck
 Re: 29083; Ontario

Date of Sampling: 04-30-2024
 Date of Receipt: 05-01-2024
 Date of Report: 05-03-2024

ASBESTOS PLM REPORT

Location: 29083-41, Concrete

Lab ID-Version‡: 17758037-1

Sample Layers	Asbestos Content
Gray Concrete	ND
Sample Composite Homogeneity: Moderate	

Location: 29083-42, Concrete

Lab ID-Version‡: 17758038-1

Sample Layers	Asbestos Content
Gray Concrete	ND
Sample Composite Homogeneity: Moderate	

Location: 29083-43, BB mastic

Lab ID-Version‡: 17758039-1

Sample Layers	Asbestos Content
White Joint Compound	ND
Off-White Mastic	ND
Gray Cove Base	ND
Sample Composite Homogeneity: Moderate	

Location: 29083-44, BB mastic

Lab ID-Version‡: 17758040-1

Sample Layers	Asbestos Content
Off-White Mastic with Brown Paper	ND
Gray Cove Base	ND
Composite Non-Asbestos Content:	5% Cellulose
Sample Composite Homogeneity: Moderate	

Comments: Some layers in the sample were inseparable without cross contamination.

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the federal government. The Company reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Aurora Industrial Hygiene, Inc.
 C/O: Mr. Robert Rinck
 Re: 29083; Ontario

Date of Sampling: 04-30-2024
 Date of Receipt: 05-01-2024
 Date of Report: 05-03-2024

ASBESTOS PLM REPORT

Location: 29083-45, BB mastic

Lab ID-Version‡: 17758041-1

Sample Layers	Asbestos Content
White Joint Compound	ND
Off-White Mastic	ND
Gray Cove Base	ND
Sample Composite Homogeneity: Moderate	

Location: 29083-46, DW/JC

Lab ID-Version‡: 17758042-1

Sample Layers	Asbestos Content
White Drywall with Brown Paper	ND
White Joint Compound	ND
Cream Tape	ND
White Joint Compound with Paint	ND
Composite Non-Asbestos Content: 10% Cellulose	
Sample Composite Homogeneity: Poor	

Location: 29083-47, DW/JC

Lab ID-Version‡: 17758043-1

Sample Layers	Asbestos Content
White Drywall with Brown Paper	ND
White Joint Compound	ND
Cream Tape	ND
White Joint Compound with Paint	ND
Composite Non-Asbestos Content: 10% Cellulose	
Sample Composite Homogeneity: Poor	

Location: 29083-48, DW/JC

Lab ID-Version‡: 17758044-1

Sample Layers	Asbestos Content
White Drywall with Brown Paper	ND
White Joint Compound	ND
Cream Tape	ND
White Joint Compound with Paint	ND
Composite Non-Asbestos Content: 10% Cellulose	
Sample Composite Homogeneity: Poor	

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the federal government. The Company reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Aurora Industrial Hygiene, Inc.
 C/O: Mr. Robert Rinck
 Re: 29083; Ontario

Date of Sampling: 04-30-2024
 Date of Receipt: 05-01-2024
 Date of Report: 05-03-2024

ASBESTOS PLM REPORT

Location: 29083-49, Carpet glue

Lab ID-Version‡: 17758045-1

Sample Layers	Asbestos Content
Yellow Glue	ND
Blue Carpet	ND
Composite Non-Asbestos Content:	60% Synthetic Fibers
Sample Composite Homogeneity:	Moderate

Location: 29083-50, Carpet glue

Lab ID-Version‡: 17758046-1

Sample Layers	Asbestos Content
Yellow Glue	ND
Blue Carpet	ND
Composite Non-Asbestos Content:	60% Synthetic Fibers
Sample Composite Homogeneity:	Moderate

Location: 29083-51, Carpet glue

Lab ID-Version‡: 17758047-1

Sample Layers	Asbestos Content
Yellow Glue	ND
Blue Carpet	ND
Composite Non-Asbestos Content:	60% Synthetic Fibers
Sample Composite Homogeneity:	Moderate

Location: 29083-52, BB mastic

Lab ID-Version‡: 17758048-1

Sample Layers	Asbestos Content
Yellow Mastic	ND
Gray Cove Base	ND
Sample Composite Homogeneity:	Moderate

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the federal government. The Company reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Aurora Industrial Hygiene, Inc.
 C/O: Mr. Robert Rinck
 Re: 29083; Ontario

Date of Sampling: 04-30-2024
 Date of Receipt: 05-01-2024
 Date of Report: 05-03-2024

ASBESTOS PLM REPORT

Location: 29083-53, BB mastic

Lab ID-Version‡: 17758049-1

Sample Layers	Asbestos Content
White Joint Compound	ND
Off-White Mastic	ND
Gray Cove Base	ND
Sample Composite Homogeneity: Moderate	

Location: 29083-54, BB mastic

Lab ID-Version‡: 17758050-1

Sample Layers	Asbestos Content
White Joint Compound	ND
Off-White Mastic	ND
Gray Cove Base	ND
Sample Composite Homogeneity: Moderate	

Location: 29083-55, VFT with mastic

Lab ID-Version‡: 17758051-1

Sample Layers	Asbestos Content
Black Mastic	ND
Tan Floor Tile	ND
Yellow Mastic	ND
Sample Composite Homogeneity: Moderate	

Location: 29083-56, VFT with mastic

Lab ID-Version‡: 17758052-1

Sample Layers	Asbestos Content
Black Mastic	ND
Tan Floor Tile	ND
Yellow Mastic	ND
Sample Composite Homogeneity: Moderate	

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the federal government. The Company reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Aurora Industrial Hygiene, Inc.
 C/O: Mr. Robert Rinck
 Re: 29083; Ontario

Date of Sampling: 04-30-2024
 Date of Receipt: 05-01-2024
 Date of Report: 05-03-2024

ASBESTOS PLM REPORT

Location: 29083-57, VFT with mastic

Lab ID-Version‡: 17758053-1

Sample Layers	Asbestos Content
Black Mastic	ND
Tan Floor Tile	ND
Yellow Mastic	ND
Sample Composite Homogeneity:	Moderate

Location: 29083-58, Carpet glue

Lab ID-Version‡: 17758054-1

Sample Layers	Asbestos Content
Off-White Glue	ND
Blue Carpet	ND
Composite Non-Asbestos Content:	60% Synthetic Fibers
Sample Composite Homogeneity:	Moderate

Location: 29083-59, Carpet glue

Lab ID-Version‡: 17758055-1

Sample Layers	Asbestos Content
Yellow Glue	ND
Blue Carpet	ND
Composite Non-Asbestos Content:	60% Synthetic Fibers
Sample Composite Homogeneity:	Moderate

Location: 29083-60, Carpet glue

Lab ID-Version‡: 17758056-1

Sample Layers	Asbestos Content
Yellow Glue	ND
Blue Carpet	ND
Composite Non-Asbestos Content:	60% Synthetic Fibers
Sample Composite Homogeneity:	Moderate

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the federal government. The Company reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Aurora Industrial Hygiene, Inc.
 C/O: Mr. Robert Rinck
 Re: 29083; Ontario

Date of Sampling: 04-30-2024
 Date of Receipt: 05-01-2024
 Date of Report: 05-03-2024

ASBESTOS PLM REPORT

Location: 29083-61, BB mastic

Lab ID-Version‡: 17758057-1

Sample Layers	Asbestos Content
White Drywall with Brown Paper	ND
Off-White Mastic	ND
Gray Cove Base	ND
Composite Non-Asbestos Content:	5% Cellulose
Sample Composite Homogeneity:	Poor

Location: 29083-62, BB mastic

Lab ID-Version‡: 17758058-1

Sample Layers	Asbestos Content
White Joint Compound	ND
Off-White Mastic	ND
Gray Cove Base	ND
Sample Composite Homogeneity:	Poor

Location: 29083-63, BB mastic

Lab ID-Version‡: 17758059-1

Sample Layers	Asbestos Content
White Joint Compound	ND
Off-White Mastic	ND
Gray Cove Base	ND
Sample Composite Homogeneity:	Poor

Location: 29083-64, VFT with mastic

Lab ID-Version‡: 17758060-1

Sample Layers	Asbestos Content
Black Mastic	ND
Tan Floor Tile	ND
Yellow Mastic	ND
Sample Composite Homogeneity:	Moderate

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the federal government. The Company reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by -"x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Aurora Industrial Hygiene, Inc.
 C/O: Mr. Robert Rinck
 Re: 29083; Ontario

Date of Sampling: 04-30-2024
 Date of Receipt: 05-01-2024
 Date of Report: 05-03-2024

ASBESTOS PLM REPORT

Location: 29083-65, VFT with mastic

Lab ID-Version‡: 17758061-1

Sample Layers	Asbestos Content
Black Mastic	ND
Tan Floor Tile	ND
Yellow Mastic	ND
Sample Composite Homogeneity:	Moderate

Location: 29083-66, VFT with mastic

Lab ID-Version‡: 17758062-1

Sample Layers	Asbestos Content
Black Mastic	ND
Tan Floor Tile	ND
Yellow Mastic	ND
Sample Composite Homogeneity:	Moderate

Location: 29083-67, Carpet glue

Lab ID-Version‡: 17758063-1

Sample Layers	Asbestos Content
Gray Cementitious Material	ND
Gray Glue	ND
Blue Carpet	ND
Composite Non-Asbestos Content:	60% Synthetic Fibers
Sample Composite Homogeneity:	Poor

Location: 29083-68, Carpet glue

Lab ID-Version‡: 17758064-1

Sample Layers	Asbestos Content
Yellow Glue with Gray Cementitious Material	ND
Blue Carpet	ND
Composite Non-Asbestos Content:	60% Synthetic Fibers
Sample Composite Homogeneity:	Poor

Comments: Some layers in the sample were inseparable without cross contamination.

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the federal government. The Company reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by -"x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Aurora Industrial Hygiene, Inc.
 C/O: Mr. Robert Rinck
 Re: 29083; Ontario

Date of Sampling: 04-30-2024
 Date of Receipt: 05-01-2024
 Date of Report: 05-03-2024

ASBESTOS PLM REPORT

Location: 29083-69, Carpet glue

Lab ID-Version‡: 17758065-1

Sample Layers	Asbestos Content
Yellow Glue with Gray Cementitious Material	ND
Blue Carpet	ND
Composite Non-Asbestos Content:	60% Synthetic Fibers
Sample Composite Homogeneity:	Poor

Comments: Some layers in the sample were inseparable without cross contamination.

Location: 29083-70, BB mastic

Lab ID-Version‡: 17758066-1

Sample Layers	Asbestos Content
White Mastic	ND
White Joint Compound with Paint	ND
Sample Composite Homogeneity:	Moderate

Comments: Baseboard was not detected.

Location: 29083-71, BB mastic

Lab ID-Version‡: 17758067-1

Sample Layers	Asbestos Content
White Mastic	ND
White Joint Compound with Paint	ND
Sample Composite Homogeneity:	Moderate

Comments: Baseboard was not detected.

Location: 29083-72, BB mastic

Lab ID-Version‡: 17758068-1

Sample Layers	Asbestos Content
White Mastic	ND
White Joint Compound with Paint	ND
Sample Composite Homogeneity:	Moderate

Comments: Baseboard was not detected.

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the federal government. The Company reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Aurora Industrial Hygiene, Inc.
 C/O: Mr. Robert Rinck
 Re: 29083; Ontario

Date of Sampling: 04-30-2024
 Date of Receipt: 05-01-2024
 Date of Report: 05-03-2024

ASBESTOS PLM REPORT

Location: 29083-73, Grout

Lab ID-Version‡: 17758069-1

Sample Layers	Asbestos Content
Gray Grout	ND
Sample Composite Homogeneity: Moderate	

Location: 29083-74, Grout

Lab ID-Version‡: 17758070-1

Sample Layers	Asbestos Content
Brown Grout	ND
Sample Composite Homogeneity: Moderate	

Location: 29083-75, Grout

Lab ID-Version‡: 17758071-1

Sample Layers	Asbestos Content
Brown Grout	ND
Sample Composite Homogeneity: Moderate	

Location: 29083-76, Wall mastic

Lab ID-Version‡: 17758072-1

Sample Layers	Asbestos Content
Orange Mastic	ND
Sample Composite Homogeneity: Moderate	

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the federal government. The Company reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Aurora Industrial Hygiene, Inc.
 C/O: Mr. Robert Rinck
 Re: 29083; Ontario

Date of Sampling: 04-30-2024
 Date of Receipt: 05-01-2024
 Date of Report: 05-03-2024

ASBESTOS PLM REPORT

Location: 29083-77, Wall mastic

Lab ID-Version‡: 17758073-1

Sample Layers	Asbestos Content
Orange Mastic	ND
Sample Composite Homogeneity:	Moderate

Location: 29083-78, Wall mastic

Lab ID-Version‡: 17758074-1

Sample Layers	Asbestos Content
Orange Mastic with Silver Foil	ND
Composite Non-Asbestos Content:	15% Cellulose 5% Glass Fibers
Sample Composite Homogeneity:	Moderate

Comments: Sample layers inseparable without cross contamination.

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the federal government. The Company reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

East: (866) 871-1984
 Central: (800) 651-4802
 West: (866) 888-6653

WEATHER		Fog	Rain	Snow	Wind	Clear
LEVEL	None					
	Light					
	Moderate					
	Heavy					

REQUESTED SERVICES				
Non-Culturable		Culturable		Other Requests
Spore Trap	Tape, Swab, Bulk	BioCassette™ Andersen, SAS, Swab, Water, Bulk, Dust, Soil, Contact Plate		
Spore Trap Analysis	Other biological particles - supplement	1-Media Surface Fungi (Genus ID + Asp. spp.)	Asbestos in Air - PCM Airborne Fiber Count (NIOSH 7400)	X ↓
Direct Microscopic Exam (Qualitative)	Quantitative spore count direct exam	Culturable Air Fungi (Genus ID + Asp. spp.)	Asbestos Bulk - PLM	
Dust Characterization		Gram Stain and Counts (Culturable Air and Surface Bacteria)	Lead (Pb) - Flame AA	
		Legionella culture	PCR (please specify test)	
		Total Coliform, E.coli (Presence/Absence)	Allergens (please specify test)	
		QuantTray-Sewage Screen		
		OTHER: (please specify test)		

CONTACT INFORMATION	
Company: AURORA	Address:
Contact: BOB RINCK	Special Instructions:
Phone: 213 445-9836	



PROJECT INFORMATION		TURN AROUND TIME CODES - (TAT)	
Project ID: 29083	STD - Standard (Default)	Rushes received after 2pm or on weekends, will be considered received the next business day. Please alert us in advance of weekend analysis needs.	
Project Description: ONTARIO	ND - Next Business Day		
Project Zip Code:	SD - Same Business Day		
PO Number:	WH - Weekend/Holiday/ASAP		
Sampling Date/Time: 4-30-24			
Sampled By: R. RINCK			

SAMPLE ID	DESCRIPTION	Sample Type (Below)	TAT (Above)	Total Volume/Area (as applicable)	NOTES (Time of day, Temp, RH, etc.)
29083-01	CONCRETE	B	STD		
02	"				
03	"				
04	MORTAR				
05	"				
06	"				
07	CARPET GLUE				
08	"				
09	"				
10	VFT w/ MASTIC				
11	"				
12	"				
13	BB MASTIC				
14	"				
15	"				


SAMPLE TYPE CODES				RELINQUISHED BY	DATE & TIME	RECEIVED BY	DATE & TIME
BC - BioCassette™	CP - Contact Plate	T - Tape	O - Other:	ROBERT RINCK	5-1-24	Ani mode	5/1/24
A1S - Andersen	ST - Spore Trap	SW - Swab		J.R.	1000		9:32
SAS - Surface Air Sampler	B - Bulk	SO - Soil					
NP - Non-potable Water	P - Potable Water	D - Dust					

East: (866) 871-1984
 Central: (800) 651-4802
 West: (866) 888-6653

WEATHER		Fog	Rain	Snow	Wind	Clear
LEVEL	None					
	Light					
	Moderate					
	Heavy					


REQUESTED SERVICES				
Non-Culturable		Culturable		Other Requests
Spore Trap	Tape, Swab, Bulk	BioCassette™ Andersen, SAS, Swab, Water, Bulk, Dust, Soil, Contact Plate		
Spore Trap Analysis	Other biological particles - supplement	1-Media Surface Fungi (Genus ID + Asp. spp.)	Asbestos in Air - PCM Airborne Fiber Count (NIOSH 7400)	Asbestos Bulk - PLM Lead (Pb) - Flame AA PCR (please specify test) Allergens (please specify test)
Direct Microscopic Exam (Qualitative)	Quantitative spore count direct exam	Culturable Air Fungi (Genus ID + Asp. spp.)	Asbestos Bulk - PLM	
Dust Characterization		Gram Stain and Counts (Culturable Air and Surface Bacteria)	Lead (Pb) - Flame AA	
		Legionella culture	PCR (please specify test)	
		Total Coliform, E.coli (Presence/Absence)	Allergens (please specify test)	
		QuantTray-Sewage Screen		
		OTHER: (please specify test)		

CONTACT INFORMATION	
Company: AURORA	Address:
Contact:	Special Instructions:
Phone:	



PROJECT INFORMATION		TURN AROUND TIME CODES - (TAT)	
Project ID: 29083		STD - Standard (Default)	Rushes received after 2pm or on weekends, will be considered received the next business day. Please alert us in advance of weekend analysis needs.
Project Description:		ND - Next Business Day	
Project Zip Code:	Sampling Date/Time:	SD - Same Business Day	
PO Number:	Sampled By:	WH - Weekend/Holiday/ASAP	

SAMPLE ID	DESCRIPTION	Sample Type (Below)	TAT (Above)	Total Volume/Area (as applicable)	NOTES (Time of day, Temp, RH, etc.)
29083-16	DW/JC	B	STD		
17	"				
18	"				
19	2x4 CT				
20	"				
21	"				
22	MORTAR				
23	"				
24	"				
25	12x12 VFT w/MASTIC				
26	"				
27	"				
28	DW/JC				
29	"				
30	"				

SAMPLE TYPE CODES				RELINQUISHED BY	DATE & TIME
BC - BioCassette™	CP - Contact Plate	T - Tape	O - Other:		
A1S - Andersen	ST - Spore Trap	SW - Swab			
SAS - Surface Air Sampler	B - Bulk	SO - Soil			
NP - Non-potable Water	P - Potable Water	D - Dust			

RECEIVED BY	DATE & TIME
Ani Modh	5/12/24
	9:35

East: (866) 871-1984
 Central: (800) 651-4802
 West: (866) 888-6653

WEATHER		Fog	Rain	Snow	Wind	Clear
LEVEL	None					
	Light					
	Moderate					
	Heavy					

CONTACT INFORMATION	
Company: Aurotek	Address:
Contact:	Special Instructions:
Phone:	




PROJECT INFORMATION		TURN AROUND TIME CODES - (TAT)	
Project ID: 29083		STD - Standard (Default)	Rushes received after 2pm or on weekends, will be considered received the next business day. Please alert us in advance of weekend analysis needs.
Project Description:		ND - Next Business Day	
Project Zip Code:	Sampling Date/Time:	SD - Same Business Day	
PO Number:	Sampled By:	WH - Weekend/Holiday/ASAP	

REQUESTED SERVICES			
Non-Culturable		Culturable	
Spore Trap	Tape, Swab, Bulk	BioCassette™ Andersen, SAS, Swab, Water, Bulk, Dust, Soil, Contact Plate	Other Requests
Spore Trap Analysis	Other biological particles - supplement	1-Media Surface Fungi (Genus ID + Asp. spp.)	Asbestos in Air - PCM Airborne Fiber Count (NIOSH 7400)
Direct Microscopic Exam (Qualitative)	Quantitative spore count direct exam	Culturable Air Fungi (Genus ID + Asp. spp.)	Asbestos Bulk - P1 M
Dust Characterization		Gram Stain and Counts (Culturable Air and Surface Bacteria)	Lead (Pb) - Flame AA
		Legionella culture	PCR (please specify test)
		Total Coliform, E.coli (Presence/Absence)	Allergen (please specify test)
		Quantil Tray-Sewage Screen	
		OTHER: (please specify test)	

SAMPLE ID	DESCRIPTION	Sample Type (Below)	TAT (Above)	Total Volume/Area (as applicable)	NOTES (Time of day, Temp, RH, etc.)
29083-31	BB MASTIC	B	STD		
32	"				
33	"				
34	TERRAZZO				
35	"				
36	"				
37	SEAL/GROUT				
38	"				
39	"				
40	CONCRETE				
41	"				
42	"				
43	BB MASTIC				
44	"				
45	"				

SAMPLE TYPE CODES			
BC - BioCassette™	CP - Contact Plate	T - Tape	O - Other:
A1S - Andersen	ST - Spore Trap	SW - Swab	
SAS - Surface Air Sampler	B - Bulk	SO - Soil	
NP - Non-potable Water	P - Potable Water	D - Dust	

RELINQUISHED BY	DATE & TIME
	

RECEIVED BY	DATE & TIME
Anni Moch	11/29
	9:31

East: (866) 871-1984
 Central: (800) 651-4802
 West: (866) 888-6653


LEVEL	WEATHER	Fog	Rain	Snow	Wind	Clear
	None					
	Light					
	Moderate					
	Heavy					

REQUESTED SERVICES

Non-Culturable		Culturable		Other Requests
Spore Trap	Tape, Swab, Bulk	BioCassette™ Swab, Water, Bulk, Dust, Soil, Contact Plate	Andersen, SAS, Swab, Water, Bulk, Dust, Soil, Contact Plate	

CONTACT INFORMATION

Company: **AURORA** Address: _____
 Contact: _____ Special Instructions: _____
 Phone: _____



PROJECT INFORMATION

Project ID: **29083**

TURN AROUND TIME CODES - (TAT)

STD - Standard (Default)
 ND - Next Business Day
 SD - Same Business Day
 WH - Weekend/Holiday/ASAP

Rushes received after 2pm or on weekends, will be considered received the next business day. Please alert us in advance of weekend analysis needs.

SAMPLE ID	DESCRIPTION	Sample Type (Below)	TAT (Above)	Total Volume/Area (as applicable)	NOTES (Time of day, Temp, RH, etc.)
29083-46	DW/JC	B	STD		
47	"				
48	"				
49	CARPET GLOE GLUE				
50	"				
51	"				
52	BB MASTIC				
53	"				
54	"				
55	VFT w/MASTIC				
56	"				
57	"				
58	CARPET GLUE				
59	"				
60	"				

Spore Trap Analysis	Other biological pericles - supplement	Direct Microscopic Exam (Qualitative)	Quantitative spore count direct exam	Dust Characterization	I-Media Surface Fungi (Genus ID + Asp spp.)	Culturable Air Fungi (Genus ID + Asp spp.)	Gram Stain and Counts (Culturable Air and Surface Bacteria)	Legionella culture	Total Coliform, E coli (Presence/Absence)	Quantal Tray Sewage Screen	OTHER: (please specify test)	Asbestos in Air - PCM Airborne Fiber Count (NIOSH 7400)	Asbestos Bulk - PLM	Lead (Pb) - Flame AA	PCR (Please specify test)	Allergens (please specify test)
---------------------	--	---------------------------------------	--------------------------------------	-----------------------	---	--	---	--------------------	---	----------------------------	------------------------------	---	---------------------	----------------------	---------------------------	---------------------------------

SAMPLE TYPE CODES

BC - BioCassette™	CP - Contact Plate	T - Tape	O - Other:
A1S - Andersen	ST - Spore Trap	SW - Swab	
SAS - Surface Air Sampler	B - Bulk	SO - Soil	
NP - Non-potable Water	P - Potable Water	D - Dust	

RELINQUISHED BY

[Signature]

DATE & TIME

RECEIVED BY

Ani moch

DATE & TIME

5/1/24
9:30

East: (866) 871-1984
 Central: (800) 651-4802
 West: (866) 888-6653

WEATHER		Fog	Rain	Snow	Wind	Clear
LEVEL	None					
	Light					
	Moderate					
	Heavy					

REQUESTED SERVICES

Non-Culturable		Culturable	Other Requests
Spore Trap	Tape, Swab, Bulk	BioCassette™ Andersen, SAS Swab, Water, Bulk, Dust, Soil, Contact Plate	

CONTACT INFORMATION	
Company: AURORA	Address:
Contact:	Special Instructions:
Phone:	





PROJECT INFORMATION		TURN AROUND TIME CODES - (TAT)	
Project ID: 29083		STD - Standard (Default)	Rushes received after 2pm or on weekends, will be considered received the next business day. Please alert us in advance of weekend analysis needs.
Project Description:		ND - Next Business Day	
Project Zip Code:	Sampling Date/Time:	SD - Same Business Day	
PO Number:	Sampled By:	WH - Weekend/Holiday/ASAP	

SAMPLE ID	DESCRIPTION	Sample Type (Below)	TAT (Above)	Total Volume/Area (as applicable)	NOTES (Time of day, Temp, RH, etc.)
29083-61	BB MASTIC	B	STD		
62	"				
63	"				
64	VFT w/MASTIC				
65	"				
66	"				
67	CARPET GLUE				
68	"				
69	"				
70	BB MASTIC				
71	"				
72	"				
73	GROUT				
74	"				
75	"				

Spore Trap Analysis	Other biological particles - supplement	Direct Microscopic Exam (Qualitative)	Quantitative spore count direct exam	Dust Characterization	1-Media Surface Fungi (Genus ID + Asp. spp.)	Culturable Air Fungi (Genus ID + Asp. spp.)	Gram Stain and Counts (Culturable Air and Surface Bacteria)	Legionella culture	Total Coliform, E. coli (Presence/Absence)	QuantTray Sewage Screen	OTHER: (please specify test)	Asbestos in Air - PCM Airborne Fiber Count (NIOSH 7400)	Asbestos Bulk - PLM	Lead (Pb) - Flame AA	PCR (please specify test)	Allergens (please specify test)
---------------------	---	---------------------------------------	--------------------------------------	-----------------------	--	---	---	--------------------	--	-------------------------	------------------------------	---	---------------------	----------------------	---------------------------	---------------------------------

SAMPLE TYPE CODES			
BC - BioCassette™	CP - Contact Plate	T - Tape	O - Other:
A1S - Andersen	ST - Spore Trap	SW - Swab	
SAS - Surface Air Sampler	B - Bulk	SO - Soil	
NP - Non-potable Water	P - Potable Water	D - Dust	

RELINQUISHED BY	DATE & TIME
	

RECEIVED BY	DATE & TIME
	5/11/23
	9:32

East: (866) 871-1984
 Central: (800) 651-4802
 West: (866) 888-6653

WEATHER		Fog	Rain	Snow	Wind	Clear
LEVEL	None					
	Light					
	Moderate					
	Heavy					

6

REQUESTED SERVICES			
Non-Culturable		Culturable	Other Requests
Spore Trap	Tape, Swab, Bulk	BioCassette™ Andersen, SAS, Swab, Water, Bulk, Dust, Soil, Contact Plate	
Spore Trap Analysis	Other biological particulates - supplement	1-Media Surface Fungi (Genus ID + Asp. spp.) Culturable Air Fungi (Genus ID + Asp. spp.) Gram Stain and Counts (Culturable Air and Surface Bacteria) Legionella culture Total Coliform, E.coli (Presence/Absence) Quantitray-Sewage Screen OTHER: (please specify test)	Asbestos in Air - PCM Airborne Fiber Count (NIOSH 7400) Asbestos Bulk - PLM Lead (Pb) - Flame AA PCR (please specify test) Allergens (please specify test)
Direct Microscopic Exam (Qualitative)	Quantitative spore count direct exam		
Dust Characterization			

CONTACT INFORMATION

Company: Auroch Address: _____
 Contact: _____ Special Instructions: _____
 Phone: _____



PROJECT INFORMATION

Project ID: 29083 TUF _____ (AT)

Description: _____ STD - Standard (Default) Rushes received after 2pm or on weekends, will be considered received the next business day. Please alert us in advance of weekend analysis needs.

Zip Code: _____ Sampling Date/Time: _____ SD - Same Business Day
 PO Number: _____ By: _____ WH - Weekend/Holiday/ASAP

SAMPLE ID	DESCRIPTION	Sample Type (Below)	TAT (Above)	Total Volume/Area (as applicable)	NOTES (Time of day, Temp, RH, etc.)
<u>29083-76</u> ↓ <u>77</u> <u>78</u>	<u>WALL MASTK</u> <u>1</u> <u>11</u>	<u>3</u> ↓	<u>STD</u> ↓		

SAMPLE TYPE CODES

BC - BioCassette™	CP - Contact Plate	T - Tape	O - Other:
A1S - Andersen	ST - Spore Trap	SW - Swab	
SAS - Surface Air Sampler	B - Bulk	SO - Soil	
NP - Non-potable Water	P - Potable Water	D - Dust	

RELINQUISHED BY [Signature] **DATE & TIME** _____

RECEIVED BY [Signature] **DATE & TIME** 11/12
9:30

Certifications/8552 Form



STATE OF CALIFORNIA
DEPARTMENT OF PUBLIC HEALTH



LEAD-RELATED CONSTRUCTION CERTIFICATE

INDIVIDUAL:	CERTIFICATE TYPE:	NUMBER:	EXPIRATION DATE:
	Lead Project Monitor	LRC-00002722	10/14/2024
	Lead Inspector/Assessor	LRC-00002723	10/14/2024

Robert Rinck

Disclaimer: This document alone should not be relied upon to confirm certification status. Compare the individual's photo and name to another valid form of government issued photo identification. Verify the individual's certification status by searching for Lead-Related Construction Professionals at www.cdph.ca.gov/programs/clppb or calling (800) 597-LEAD

State of California
Division of Occupational Safety and Health
Certified Asbestos Consultant

Robert Andrew Rinck
Name



Certification No. **03-3374**

Expires on **07/31/24**

This certification was issued by the Division of Occupational Safety and Health as authorized by Sections 7180 et seq. of the Business and Professions Code.



STATE OF CALIFORNIA
DEPARTMENT OF PUBLIC HEALTH



LEAD-RELATED CONSTRUCTION CERTIFICATE

INDIVIDUAL:



David Robey

CERTIFICATE TYPE:

Lead Sampling Technician

NUMBER:

LRC-00011237

EXPIRATION DATE:

5/22/2025

Disclaimer: This document alone should not be relied upon to confirm certification status. Compare the individual's photo and name to another valid form of government issued photo identification. Verify the individual's certification status by searching for Lead-Related Construction Professionals at www.cdph.ca.gov/programs/clppb or calling (800) 597-LEAD

LEAD HAZARD EVALUATION REPORT**Section 1 — Date of Lead Hazard Evaluation** April 30, 2024**Section 2 — Type of Lead Hazard Evaluation (Check one box only)**
 Lead Inspection
 Risk assessment
 Clearance Inspection
 Other (specify) _____
Section 3 — Structure Where Lead Hazard Evaluation Was Conducted

Address [number, street, apartment (if applicable)]

2500 S Archibald Ave

City

Ontario

County

San Bernardino

Zip Code

91764Construction date (year)
of structureUnknown

Type of structure

 Multi-unit building School or daycare

Children living in structure?

 Yes No Single family dwelling Other Police Sta Don't Know**Section 4 — Owner of Structure (if business/agency, list contact person)**

Name

City of Ontario

Telephone number

909-395-2000

Address [number, street, apartment (if applicable)]

303 East B Street

City

Ontario

State

CA

Zip Code

91764**Section 5 — Results of Lead Hazard Evaluation (check all that apply)**
 No lead-based paint detected
 Intact lead-based paint detected
 Deteriorated lead-based paint detected

 No lead hazards detected
 Lead-contaminated dust found
 Lead-contaminated soil found
 Other _____
Section 6 — Individual Conducting Lead Hazard Evaluation

Name

Robert Rinck

Telephone number

626-403-4104

Address [number, street, apartment (if applicable)]

2667 E 28th Street, Suite 512

City

Signal Hill

State

CA

Zip Code

90755

CDPH certification number

LRC00002723

Signature



Date

May 15, 2024

Name and CDPH certification number of any other individuals conducting sampling or testing (if applicable)

Section 7 — Attachments

- A. A foundation diagram or sketch of the structure indicating the specific locations of each lead hazard or presence of lead-based paint;
- B. Each testing method, device, and sampling procedure used;
- C. All data collected, including quality control data, laboratory results, including laboratory name, address, and phone number.

First copy and attachments retained by inspector

Second copy and attachments retained by owner

Third copy only (no attachments) mailed or faxed to:

California Department of Public Health
 Childhood Lead Poisoning Prevention Branch Reports
 850 Marina Bay Parkway, Building P, Third Floor
 Richmond, CA 94804-6403
 Fax: (510) 620-5656